



Revisions	Date

Toland ♦ Mizell ♦ Molnar, LLC

590 MEANS STREET NW,
SUITE 200
ATLANTA, GA, 30318
404-214-9774

Drawing Title	Project Title
SECOND FLOOR ELECTRICAL PLAN - LIGHTING	2ND FLOOR OUTPATIENT MENTAL HEALTH

Approved Project Engineer	Building Number	Checked	Drawn
	BLDG 1 SOUTH WING	RBP	TWG
	Location	VA MEDICAL CENTER SHREVEPORT, LOUISIANA	

Date	Project No.	Drawing No.
05-26-2011	VA256-C-1047	E101

NORTH

100% REVIEW
SUBMITTAL

Veterans
Administration



- NOTES:**
(THIS SHEET ONLY)
- 1 PROVIDE DUAL SWITCHING FOR LIGHTING IN THIS SPACE. SWITCH OUTBOARD LAMPS ON FIRST SWITCH AND INBOARD LAMPS ON SECOND SWITCH.
 - 2 MAKE CONNECTIONS TO EXISTING LIGHTING CIRCUIT AT STAIRWELL AREA ON FLOORS BELOW.
 - 3 THIS FUTURE SHALL BE UNSWITCHED.
 - 4 ROUTE 2#12#126.3/4°C TO EXISTING BUILDING LIFE SAFETY ELECTRICAL PANEL LIGHT LOCATED ON BASEMENT FLOOR. PROVIDE 20 AMP/1" POLE BREAKERS IN SPACE AVAILABLE AND MAKE ALL CONNECTIONS AS REQUIRED.
 - 5 MAKE CONNECTIONS TO EXISTING LIGHTING CIRCUIT AT STAIRWELL AREA ON FLOORS BELOW.
 - 6 THIS FUTURE SHALL BE UNSWITCHED.
 - 7 MAKE ALL CONNECTIONS TO EXISTING LIFE SAFETY LIGHTING CIRCUIT IN CORRIDOR.
 - 8 MAKE ALL CONNECTIONS TO EXISTING NORMAL POWER LIGHTING CIRCUIT IN CORRIDOR.
 - 9 COORDINATE EXACT LOCATION OF SWITCHES WITH VA FOR ELEVATOR LOBBY PRIOR TO INSTALLATION.