



SECOND FLOOR ELECTRICAL PLAN – POWER

SCALE: 1/8" = 1'-0"

NOTES:  
(THIS SHEET ONLY)

- 1 MAKE ALL CONNECTIONS TO EXISTING RECEPTACLE CIRCUIT IN STAIRWELL FROM EXISTING FLOORS BELOW.
- 2 30 AMP 7/3 POLE/NEUA 3P NON-FUSED DISCONNECT. MAKE ALL CONNECTIONS TO EXHAUST FANS AS REQUIRED.
- 3 ROUTE VIA STARTER IN MECHANICAL ROOM.
- 4 PROVIDE (2) SIZE 0, FOUR STARTERS. COORDINATE EXACT MOUNTING LOCATION.
- 5 60 AMP 7/3 POLE FUSED DISCONNECT, FUSED AT 50 AMPS.
- 6 ROUTE VIA VFD IN MECHANICAL ROOM.
- 7 30 AMP 7/3 POLE NON-FUSED DISCONNECT FOR 120V LIGHTING CIRCUIT IN AHU-2. MAKE ALL CONNECTIONS TO AS REQUIRED.
- 8 POWER CONNECTION TO POWER SUPPLIES FOR DOOR HOLD OPEN DEVICES.
- 9 POWER CONNECTIONS TO PANIC ALARM SYSTEM CONTROL PANEL. COORDINATE EXACT MOUNTING LOCATION PRIOR TO INSTALLATION.
- 10 MAKE ALL CONNECTIONS TO EXISTING NORMAL POWER RECEPTACLE CIRCUIT LEFT ABANDONED IN THIS SPACE.
- 11 PROVIDE RECEPTACLE FOR SUMP PUMP IN SUMP PUMP PIT AT LOCATION BELOW BASEMENT LEVEL. COORDINATE EXACT LOCATION PRIOR TO ROUGHING.
- 12 PROVIDE MOTOR RATED SWITCH FOR POWER CONNECTION TO SMOKE DAMPER. COORDINATE EXACT LOCATION PRIOR TO INSTALLATION.
- 13 PROVIDE POWER CONNECTION TO CONTROL SWITCH FOR HVAC SYSTEM. COORDINATE EXACT LOCATION.

Revisions	Date

Toland ♦ Mizell ♦ Molnar, LLC

590 MEANS STREET NW,  
SUITE 200  
ATLANTA, GA, 30318  
404-214-9774

Drawing Title
SECOND FLOOR OUTPATIENT ELECTRICAL PLAN – POWER
Approved Project Engineer

Project Title
2ND FLOOR OUTPATIENT MENTAL HEALTH
Building Number
BLOC 1 SOUTH WING
Location
VA MEDICAL CENTER SHREVEPORT, LOUISIANA

100% REVIEW SUBMITTAL
Date
05-26-2011
Project No.
VA256-C-1047
DWG. NO.
E102
Dwg. Of
Veterans Administration