



- NOTES:
- (THIS SHEET ONLY)
- 1

MAKE CONNECTIONS TO EXISTING LIGHTING CIRCUIT AT STAIRWELL AREA ON FLOORS BELOW.
- 2

THIS FIXTURE SHALL BE UNSWITCHED.
- 3

MAKE ALL CONNECTIONS TO EXISTING LIFE SAFETY LIGHTING CIRCUIT IN CORRIDOR.
- 4

MAKE ALL CONNECTIONS TO EXISTING NORMAL POWER LIGHTING CIRCUIT IN CORRIDOR.
- 5

COORDINATE EXACT LOCATION OF SWITCHES WITH VA FOR ELEVATOR LOBBY PRIOR TO INSTALLATION.
- 6

MAKE ALL CONNECTIONS TO EXISTING NORMAL POWER LIGHTING CIRCUIT LEFT ABANDONED IN THIS SPACE.
- 7

NO NEW WORK REQUIRED IN THIS SPACE.

ENLARGED FLOOR PLAN

5TH FLOOR STAIRS – ELECTRICAL LIGHTING

SCALE: 1/4" = 1'-0"

ENLARGED FLOOR PLAN 6TH & 7TH FLOOR STAIRS – ELECTRICAL LIGHTING

SCALE: 1/4" = 1'-0"

Revisions	Date

Toland ♦ Mizell ♦ Molnar, LLC

590 MEANS STREET NW,
SUITE 200
ATLANTA, GA, 30318
404-214-9774

Drawing Title	FIFTH, SIXTH, AND SEVENTH STAIRS ENLARGED FLOOR PLANS ELECTRICAL LIGHTING
Approved Project Engineer	

Project Title	2ND FLOOR OUTPATIENT MENTAL HEALTH
Building Number	BLDG 1 SOUTH WING
Location	VA MEDICAL CENTER SHREVEPORT, LOUISIANA

Date	05-25-2011
Project No.	VA256-C-1047
Dwg. No.	E403

Veterans Administration

100% REVIEW

SUBMITTAL