





# ATTIC PLAN


SCALE: 1/8" = 1'-0"



NOTE 1:  
REFER TO NOTE 5 ON DRAWING E-1 FOR THE INSTALLATION  
OF FAN COIL DUCT SMOKE DETECTORS.

NOTE 2:  
EXHAUST FANS ARE LOCATED ON THE ROOF. THE ELECTRICAL CONTRACTOR  
SHALL FURNISH AND INSTALL A WEATHERPROOF SERVICE SWITCH AND  
A 120 VOLT WEATHERPROOF GFI DUPLEX RECEPTACLE TO BE MOUNTED ON  
EACH UNIT AND CONNECTED TO THE SAME CIRCUIT.

## LEGEND

-  FUSED DISCONNECT SWITCH
-  WEATHERPROOF SERVICE SWITCH
-  MOTOR
-  HOME RUN TO PANEL



 <p>Department of Veterans Affairs Medical Center Northampton, MA 01060</p>	INDUSTRIAL HYGIENIST	ELECTRICAL ENGINEER	DESIGNER/MECHANICAL ENGINEER		Drawing Title	Project Title	Date	
	DENNISON ENVIRONMENTAL 800 West Cummings Park, Suite 8500 Woburn, Massachusetts 01453 (617) 832-9400	SHEPHERD ENGINEERING 1308 Grafton Street Worcester, Massachusetts 01603 (508) 757-7783	ARA ENGINEERING ASSOCIATES, INC. 171 Main Street, Suite 103 Amherst, Massachusetts 01701 (508) 881-7432		ATTIC ELECTRICAL FLOOR PLAN	AIR QUALITY IMPROVEMENTS WARD 9	07-15-93	
					Approved: Division Chief	Building Number 9	Checked JDS	Drawn TGB
					Approved: Service Director	Location NORTHAMPTON, MASSACHUSETTS		Project No. 631-91-105  DRAWING NO. 59-24 E-2 Dwg. 11 of 12