TELEDYNE POST N37871

three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot

ZONE #6 ZONE #7

4" R.L. UP TO 4" R.D. 4" STANDPIPE & SPRINKLER UP ZONE #6 FLOW SWITCH & CONTROL VALVE
S-205 2" V.T.R. 4" R.L. DN. IN CHASE 2" V. DN. IN CHASE 2" V. DN. IN WALL
C2-3A C2-3 C2-2 C2-4
3" F.D. "M" 4" R.L. UP TO 4" R.D. 6" R.L. DN. 8" R.L. DN.
BACKFLOW DEVICE FOR MECH. DRIP PAN 2" C.R.P. V.T.R. 2" C.R.P. V. DN. IN WALL
2" V.T.R. 2" V. DN. 4" R.L. DN. IN CHASE 4" R.L. UP TO 4" R.D.
2" V. DN. IN WALL 2" V.T.R. 1" H.W.R. DN. 2" C.W. DN. 1½" H.W. DN.
2" V. DN. 1½" C.W. DN. TO STERILIZERS 1½" DN. DWR. C.W. DN. TO WASHER
2" V. DN. IN CHASE 2" V.T.R. 3" F.D. "M" 2" V. DN. DW. & DWR. DN. IN CHASE
2" C.R.P. V.T.R. 2" V. DN. 6" R.L. DN. 4" STANDPIPE DN. 2" V. DN. IN CHASE
H.V.C. 4" R.L. UP TO 4" R.D. 4" R.L. DN.
2" V. DN. IN WALL FLUSH VALVE IN RECESSED CONTROL BOX
INSPECTOR'S TEST DRAIN STANDPIPE (TYP.) DOWN. SEE DETAIL ON I-P10.
6" STANDPIPE & SPRINKLER RISER UP ZONE #7 FLOW SWITCH & CONTROL VALVE
4" R.L. UP TO 4" R.D. 4" 4" R.L. DN.

2001 2002 2003 2004 2004A 2004B 2004C 2004D 2005 2006 2007 2009 2010 2011 2013 2014 2014A 2014B 2014C 2014D 2015 2016 2017 2019 2019A 2020 2021 2022 2023 2024 2025 2025A 2025B 2025C 2025D 2025E 2025F 2025G 2025H 2026 2027 2027A 2028 2028A 2028B

P-403 P-505 P-502 P-103 P-519 P-102 P-501 P-520 P-401 N-2 3-1 5-1 1-18C

Y-2-1-2480

FULLY PROTECTED BY AUTOMATIC SPRINKLER SYSTEM

AS BUILT JUN 1 1988

Revisions Date

ODELL ASSOCIATES, INC. ARCHITECTURAL CORP. REG. ARCHITECTURAL CORP. SEAL 1570 CHARLOTTE, N.C.

KEY PLAN

NORTH CAROLINA PROFESSIONAL SEAL 5980 ENGINEER E. MARTIN KING, JR.

Planning Architecture Engineering
Odell Associates Inc. 222 South Church Street Charlotte, NC 28202
ODELL

Drawing Title: SECOND FLOOR PLAN - PLUMBING SCALE 1/8" = 1'-0"
Approved: Division Chief
Approved: Service Director
Drawn: BROWN
Checked: NYO

Project Title: CLINICAL ADDITION
Building Number: 1
Location: V.A.M.C. - FAYETTEVILLE, N.C.

Date: MAR. 29, 1985
Project No.: 565.027
DRAWING No.: I-P4
Dwg. 4 Of 14

Veterans Administration

VA FORM 08-6231, OCT 1978

U. S. GOVERNMENT PRINTING OFFICE : 1979-0-305-310