

GENERAL NOTES


- SEE MEDICAL EQUIPMENT SHEETS FOR EXACT LOCATIONS OF EQUIPMENT.
- OUTLETS SHOWN SHALL BE MOUNTED AT 18" UNLESS OTHERWISE NOTED.
- CIRCUITS SHOWN THAT CONNECT TO EXISTING PANELS SHALL BE CONNECTED AS SHOWN. IF EXISTING CIRCUIT IS IN USE, CONNECT TO SPARE CIRCUIT BREAKER IN PANEL AND AS-BUILT DRAWINGS AND PANEL SCHEDULE.
- USE EXISTING WIREWAYS LOCATED IN THE INTERSTITIAL TO DISTRIBUTE HOMERUN WIRING. INSTALL BRANCH CIRCUIT RACEWAYS (3/4" MINIMUM) FROM WIREWAYS TO FIRST DEVICE IN CIRCUIT AS SHOWN. SEAL ALL PENETRATIONS MADE THROUGH INTERSTITIAL FLOOR TO FEED DEVICES BELOW ON FLOORS ACCORDING TO VA STANDARDS. SEE SHEET'S EP-102 AND EP-103 FOR MORE INFORMATION.
- FOR SPECIAL PURPOSE OUTLETS, COORDINATE WITH EQUIPMENT PROVIDER FOR EXACT REQUIREMENTS AND PLUG CONFIGURATION.
- SEE E-600 SERIES SHEETS FOR ONE LINE DIAGRAMS AND NEW PANEL INSTALLATION DETAILS.
- ELECTRICAL ROOM LAY-OUTS ARE DIAGRAMMATICAL. FIELD VERIFY EXACT LOCATIONS.
- ALL BRANCH CIRCUITS SHALL BE A "20Y" ACCORDING TO THE FEEDER SCHEDULE UNLESS OTHERWISE NOTED.

KEYED NOTES

- PROVIDE PANEL AND TRANSFORMER. SEE E-600 SERIES SHEETS FOR MORE INFORMATION. FIELD VERIFY EXACT LOCATION FOR PLACEMENT. PROVIDE AND SECURE PANEL TO WALL AND TRANSFORMER TO FLOOR IN ACCORDANCE WITH SPECIFICATIONS 26 24 16 AND 26 22 00 FOR MORE INFORMATION.
- PROVIDE DEDICATED GFCI PROTECTED CIRCUIT FOR EWC. COORDINATE ROUGH-IN WITH PLUMBING FOR EXACT LOCATION.

A1 ELECTRICAL RECEPTACLE FLOOR PLAN - 2ND FLOOR
1/8" = 1'-0"

KEY PLAN 2ND FLOOR



COMPLETION ITEM NO. _____
FULLY SPRINKLERED

CONSULTANTS:

ARCHITECT/ENGINEERS

THE HARTMAN + MAJEWSKI
DESIGN GROUP
Architects Engineers Interior Design
Planners Urban Designers LEED®

120 Vassar Dr SE Suite 100
Albuquerque New Mexico 87106
Tel 505 242 6880 Fax 505 242 6881



Drawing Title
ELECTRICAL RECEPTACLE PLAN - 2ND FLOOR

Approved: Project Director

Project Title
AMBULATORY SURGERY EXPANSION
Building 41

Location
NMVAHCS

Date
April 22, 2011

Checked
JFH

Drawn
B&P

Project Number
6130.10

Building Number
41

Drawing Number

EJ101
Dwg. Of

Office of
Construction
and Facilities
Management

