

MC Consulting Inc.

Building 20

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
AREA 1ST FLOOR										
ROOM 100										
	BSBRD	0	NA	23 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	280 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	280 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	23 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	ACT	0	NA	280 SF	97786-	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	680 SF	97785-	WALL BRD	Y	GOOD	MOD	NO CHANGE
ROOM 100A										
	ACT	0	NA	288 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	720 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	24 SF	97783-	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	288 SF	97781-	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	288 SF	97782-	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	24 SF	97784-	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
ROOM 102										
	ACT	0	NA	108 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	480 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	16 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	16 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 104										
	ACT	0	NA	448 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	880 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	29 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	29 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
	NSINS	NA	NA	NA	NA	NSINS	NA	NA	NA	NO CHANGE
ROOM 106										
	ACT	0	NA	SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	BSBRD	0	NA	25 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	25 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
	NSINS	NA	NA	NA	NA	NSINS	NA	NA	NA	NO CHANGE
	ACT	0	NA	50 SF	97787-	2'X4' WRM W PNHL		GOOD		NO CHANGE
ROOM 108										

[illegible]

MC Consulting Inc.

Building 20

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
	ACT	0	NA	280 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
7	VFT	10	CHR	280 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	280 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
ROOM 120										
	ACT	0	NA	800 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	BSBRD	0	NA	25 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	140 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	140 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	25 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 122										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	WALL-BRD	0	NA	500 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	BSBRD	0	NA	30 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	NA	600 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	600 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	30 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	NSINS	NA	NA	NA	NA	NSINS	NA	NA	NA	NO CHANGE
ROOM 124										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
	NSINS	NA	NA	NA	NA	NSINS	NA	NA	NA	NO CHANGE
ROOM 125										
	ACT	0	NA	920 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	500 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
7	VFT	10	CHR	NA	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	NA	97782-X	MSTC FOR 97881	N	GOOD	LOW	NO CHANGE
ROOM 126										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
2	CON 50	CHR	NA	1 EA	97205-X	CMNT COND FTG	Y	GOOD	LOW	NO CHANGE
2	STM 50	CHR	NA	1 EA	97205-X	CMNT FTG STM	Y	GOOD	LOW	NO CHANGE
2	COND 65	CHR	NA	84 LF	97207-	AIRCELL COND	Y	GOOD	LOW	NO CHANGE

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
2	60	CHR	NA	12 LF	97204-	AIRCELL W/PAPER WRAP STM	Y	GOOD	LOW	NO CHANGE
2	65	CHR	NA	72 LF	97206-	AIRCELL	Y	GOOD	LOW	NO CHANGE
2	STM 50	CHR	NA	1 EA	97205-	CMNT STM	Y	GOOD	LOW	NO CHANGE
ROOM 128										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 130										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 140										
	PLAS-A	0	NA	48 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
7	PIPE-DCW	>1	NA	NA	NA	N-ACC ASSUME POSITIVE	Y	NA	LOW	Presume behind walls & above ceilings
7	PIPE-DHW	>1	NA	NA	NA	N-ACC ASSUME POSITIVE	Y	NA	LOW	Presume behind walls & above ceilings
	PLAS-W	0	NA	300 SF	97201-	PLAS	Y	GOOD	MOD	NO CHANGE
ROOM 142										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 150										
	ACT	0	NA	72 SF	97790-X	2'X4' PAT FLKS	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	360 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	BSBRD	0	NA	12 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	VFT	<1	CHR	72 SF	97791-X	1'X1' CRM W/BRN & GRY STRKS	N	GOOD	MOD	NO CHANGE
	MSTC	0	NA	12 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
7	MSTC	20	CHR	72 SF	97791-X	MSTC FOR 97791 LAB RESULTS	N	GOOD	LOW	NO CHANGE
ROOM 152										
	ACT	0	NA	168 SF	97790-X	2'X4' PAT FLKS	Y	GOOD	LOW	NO CHANGE
	PLAS-W	0	NA	500 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	20 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	VFT	<1	CHR	168 SF	97791-X	1'X1' CRM W/BRN & GRY STRKS	N	GOOD	MOD	NO CHANGE
	MSTC	0	NA	20 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
7	MSTC	20	CHR	168 SF	97791-X	MSTC FOR 97791 LAB RESULTS	N	GOOD	LOW	NO CHANGE
ROOM 154										
	PLAS-W	0	NA	300 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE

MC Consulting Inc.

Building 20

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	BSBRD	0	NA	20 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	20 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
7	MSTC	20	CHR	50 SF	97791-X	MSTC FOR 97791 LAB RESULTS	N	GOOD	LOW	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
7	PIPE-DCW	>1	NA	NA	NA	N-ACC ASSUME POSITIVE	Y	NA	LOW	Presume behind walls & above ceilings
7	PIPE-DHW	>1	NA	NA	NA	N-ACC ASSUME POSITIVE	Y	NA	LOW	Presume behind walls & above ceilings
	ACT	0	NA	50 SF	97790-	2'X4' PAT FLKS	Y	GOOD	LOW	NO CHANGE
	VFT	<1	CHR	50 SF	97791-	1'X1' CRM W/BRN & GRY STRKS	N	GOOD	MOD	NO CHANGE
ROOM 156										
	ACT	0	NA	126 SF	97790-X	2'X4' PAT FLKS	Y	GOOD	LOW	NO CHANGE
	PLAS-W	0	NA	300 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE
	WALL-BRD	0	NA	150 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0'	NA	25 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	VFT	<1	CHR	126 SF	97791-X	1'X1' CRM W/BRN & GRY STRKS	N	GOOD	MOD	NO CHANGE
	MSTC	0	NA	25 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
7	MSTC	20	CHR	126 SF	97791-X	MSTC FOR 97791 LAB RESULTS	N	GOOD	LOW	NO CHANGE
ROOM 158										
	ACT	0	NA	240 SF	97790-X	2'X4' PAT FLKS	Y	GOOD	LOW	NO CHANGE
	PLAS-W	0	NA	300 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE
	WALL-BRD	0	NA	300 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	VFT	<1	CHR	240 SF	97791-X	1'X1' CRM W/BRN & GRY STRKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	240 SF	97791-X	MSTC FOR 97791 LAB RESULTS	N	GOOD	LOW	NO CHANGE
ROOM 160										
	ACT	0	NA	128 SF	97790-X	2'X4' PAT FLKS	Y	GOOD	LOW	NO CHANGE
	PLAS-W	0	NA	450 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	25 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	25 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
7	VFT	20	CHR	64 SF	97792-	9"X9" MAR W/CRM STRK	N	FAIR	LOW	NO CHANGE
7	VFT	10	CHR	64 SF	97793-	9"X9" CRM W/BLK STRK	N	FAIR	LOW	NO CHANGE
7	MSTC	20	CHR	128 SF	97794-	MSTC FOR 97792 & 97793	N	FAIR	LOW	NO CHANGE
ROOM 162										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 164										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 168										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 170										
	WALL-BRD	0		280 SF	97785-X	WALL BRD	Y	GOOD	LOW	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM		NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
7	PIPE-DCW	>1	NA	NA	NA	N-ACC ASSUME POSITIVE	Y	GOOD	LOW	Presume behind walls & above ceilings
7	PIPE-DHW	>1	NA	NA	NA	N-ACC ASSUME POSITIVE	Y	GOOD	LOW	Presume behind walls & above ceilings
ROOM 172										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 174										
	WALL-BRD	0	NA	288 SF	97785-X	WALL BRD	Y	GOOD	LOW	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	MSTC	0	NA	288 SF	97795-X	MSTC FOR 97795 LAB RESULTS	N	FAIR	LOW	NO CHANGE
	VFT	0	NA	288 SF	97795-	1'X1'BRN W/CRM & BLK STRK	N	FAIR	MOD	NO CHANGE
ROOM 176										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
* ROOM 178										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM HW1										
	ACT	0	NA	198 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	198 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
7	VFT	10	CHR	198 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	198 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
ROOM SW1										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE

MC Consulting Inc.

Building 20

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
	VFT	0	NA	56 SF	97203-	CRM STAIR GUARD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	56 SF	97202-	MSTC FOR 97203	N	GOOD	LOW	NO CHANGE
ROOM SW2										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM SW3										
	PLAS-A	0	NA	60 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE
	PLAS-W	0	NA	120 SF	97201-X	PLAS	Y	FAIR	MOD	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM SW4										
	ACT	0	NA	36 SF	97787-X	2'X4' WRM W/PNHL	Y	GOOD	LOW	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
	VFT	0	NA	56 SF	97796-	BLK STAIR GUARD	N	FAIR	LOW	NO CHANGE
AREA 2ND FLOOR										
ROOM 200										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 202										
	ACT	0	NA	840 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	F	0	NA	840 SF	97403-X	FIREPROOFING	Y	GOOD	LOW	NO CHANGE
	PLAS-W	0	NA	200 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE
	WALL-BRD	0	NA	200 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	BSBRD	0	NA	40 SF	97788-X	4" TAN BSBRD	N	GOOD	LOW	NO CHANGE
7	MSTC	20	CHR	840 SF	97401-X	MSTC FOR 97401 LAB RESULT	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	40 SF	97789-X	MSTC FOR 97788	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	840 SF	97401-	1'X1'CRM W/ GLD FLKS	N	GOOD	MOD	NO CHANGE
ROOM 204										
	ACT	0	NA	120 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	F	0	NA	120 SF	97403-X	FIREPROOFING	Y	GOOD	LOW	NO CHANGE
	PLAS-W	0	NA	100 SF	97201-X	PLAS	Y	GOOD	MOD	NO CHANGE
	WALL-BRD	0	NA	100 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	15 SF	97788-X	4" TAN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	120 SF	97401-X	1'X1'CRM W/ GLD FLKS	N	GOOD	LOW	NO CHANGE

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
7	MSTC	20	CHR	120 SF	97401-X	MSTC FOR 97401 LAB RESULT	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	15 SF	97789-X	MSTC FOR 97788	N	GOOD	LOW	NO CHANGE
ROOM 206										
	ACT	0	NA	100 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	F	0	NA	100 SF	97403-X	FIREPROOFING	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	300 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	25 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	100 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	100 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	25 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
ROOM 208										
	ACT	0	NA	48 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	F	0	NA	50 SF	97403-X	FIREPROOFING	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	300 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	25 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	100 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	100 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
	MSTC	0		25 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
7	PIPE-DCW	>1	NA	NA	NA	N-ACC ASSUME POSITIVE	Y	NA	LOW	Presume behind walls & above ceilings
7	PIPE-DHW	>1	NA	NA	NA	N-ACC ASSUME POSITIVE	Y	NA	LOW	Presume behind walls & above ceilings
ROOM 210										
	ACT	0	NA	270 SF	97402-X	2'X4' "Y" WRM W/ PNHL	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	350 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	30 SF	97406-X	4" GRY BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	30 SF	97406-X	MSTC FOR 97406 LAB RESULTS	N	GOOD	LOW	NO CHANGE
	VFT	<1	CHR	270 SF	97404-	1'X1'GRY W/WHT STRK	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	270 SF	97405-	MSTC FOR 97404	N	GOOD	LOW	NO CHANGE
ROOM 212										
	ACT	0	NA	288 SF	97402-X	2'X4' "Y" WRM W/ PNHL	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	350 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	VFT	<1	CHR	290 SF	97404-X	1'X1'GRY W/WHT STRK	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	290 SF	97405-X	MSTC FOR 97404	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	30 SF	97406-X	MSTC FOR 97406 LAB RESULTS	N	GOOD	LOW	NO CHANGE
	BSBRD	0	NA	30 SF	97406-	4" GRY BSBRD	N	GOOD	LOW	NO CHANGE
ROOM 214										
	ACT	0	NA	384 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	F	0	NA	190 SF	97403-X	FIREPROOFING	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	300 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE

MC Consulting Inc.

Building 20

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	BSBRD	0	NA	25 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	200 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	200 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	25 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
ROOM 216										
	ACT	0	NA	400 SF	97402-X	2'X4' "Y" WRM W/ PNHL	Y	GOOD	LOW	NO CHANGE
	ACT	0	NA	400 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	600 SF	97785-X	WALL BRD	Y	GOOD	LOW	NO CHANGE
	BSBRD	0	NA	40 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
7	VFT	10	CHR	800 SF	97401-X	1'X1'CRM W/ GLD FLKS	N	GOOD	LOW	NO CHANGE
7	MSTC	20	CHR	800 SF	97401-X	MSTC FOR 97401 LAB RESULT	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	40 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
ROOM 218										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 222										
	ACT	0	NA	288 SF	97402-X	2'X4' "Y" WRM W/ PNHL	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	300 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	20 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	20 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 226										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 230										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
ROOM 250										
	ACT	0	NA	400 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	PLAS-W	0	NA	800 SF	97201-X	PLAS	Y	GOOD	LOW	NO CHANGE
	WALL-BRD	0	NA	300 SF	97785-X	WALL BRD	Y	GOOD	LOW	NO CHANGE
	BSBRD	0	NA	60 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	60 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE

LOCATION		ACM %	TYPE	QTY	SAMPLE	MATERIAL DESCRIPTION	REEVALUATION 2010			COMMENTS
RANK	FUNCTION						FRIABLE	COND	POT FOR	
							Y/N		DIST	
	ACT	0	NA	400 SF	97402-	2'X4' "Y" WRM W/ PNHL	Y	GOOD	LOW	NO CHANGE
	F	0	NA	400 SF	97403-	FIREPROOFING	Y	GOOD	LOW	NO CHANGE
ROOM 299										
	ACT	0	NA	648 SF	97787-X	2'X4' WRM W/PNHL	Y		LOW	NO CHANGE
	WALL-BRD	0	NA	500 SF	97785-X	WALL BRD	Y	GOOD	MOD	NO CHANGE
	BSBRD	0	NA	20 SF	97783-X	4" BRN BSBRD	N	GOOD	LOW	NO CHANGE
	MSTC	0	NA	20 SF	97784-X	MSTC FOR 97783	N	GOOD	LOW	NO CHANGE
	VFT	<1	CHR	60 SF	NA	1'X CRM W/WHT STRK	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	600 SF	97408-	MSTC FOR 97407	N	GOOD	LOW	NO CHANGE
ROOM SW10										
	NSCM	NA	NA	NA	NA	NSCM	NA	NA	NA	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
7	VFT	10	CHR	25 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	25 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
ROOM SW20										
	ACT	0	NA	192 SF	97786-X	2'X4' POCK MARK	Y	GOOD	LOW	NO CHANGE
	F	0	NA	84 SF	97403-X	FIREPROOFING	Y	GOOD	LOW	NO CHANGE
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
7	VFT	10	CHR	100 SF	97781-X	1'X1' CRM W/TAN FLKS	N	GOOD	MOD	NO CHANGE
7	MSTC	20	CHR	100 SF	97782-X	MSTC FOR 97781	N	GOOD	LOW	NO CHANGE
AREA PENTHOUSE										
ROOM PENT										
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE
	NSFM	NA	NA	NA	NA	NSFM	NA	NA	NA	NO CHANGE
	NSINS	NA	NA	NA	NA	NSINS	NA	NA	NA	NO CHANGE
AREA EXTERIOR										
ROOM EXT										
	NSWM	NA	NA	NA	NA	NSWM	NA	NA	NA	NO CHANGE