

Project# 502-12-102/VA256-15-R-1083 Replace Obsolete HVAC Controls - RFI ANSWERS - AMENDMENT P0010					
RFI	Item	Section	Para	Description	Response
1	Item	RFI #75	RFI # 145 Response	The response to RFI#145 does not address required new or existing duct bank locations between buildings 1, 2, 3, 9, 49, 4, 5 & 6. Can this information be provided?	Bldgs 1, 2, 3, 9, 49, 4, 5 & 6 fiber will need to be run in conduit/Arc net duct bank in the basement and pipe basements of these building. See attached drawing
2	Item	RFI #75	RFI # 145 Response	Is the routing shown on M100 between Bldgs-147, 7, 41 and 14 a fair approximation of the actual existing Arc Net duct bank routing (for purposes of estimating fiber cable length)?	For the purpose of estimating length, the VA believes it is a fair approximation.