

# SimplexGrinnell

## BE SAFE.

A business unit of Tyco Fire & Security

### Fire Alarm Equipment Test Report

SR #: 34287694

Equipment	Total Number	Number Tested This Report	Operational		
			Pass	N.A.	Fail
4. Remote Annunciators	0	0		x	
5. Transponders	0	0		x	
6. Booster Panels	0	0		x	
7. Manual Pull Stations	3	3	x		
8. Detectors					
A. Photoelectric	0	0		x	
B. Ionization	0	0		x	
C. Thermal	16	16	x		
D. Flame (UV/IR)	0	0		x	
E. Duct	0	0		x	
F. Beam	0	0		x	
G. CO	0	0		x	
9. Audio/Visuals					
A. Speaker	0	0		x	
B. Speaker/Strobe	0	0		x	
C. Horn	0	0		x	
D. Horn/Strobe	0	0		x	
E. Bell	5	5	x		
F. Bell/Strobe	0	0		x	
G. Chime	0	0		x	
H. Chime/Strobe	0	0		x	
I. Strobe Only	0	0		x	
J. Sounder Base	0	0		x	
K. Remote LED/Light	0	0		x	
10. Fireman's Phones					
A. Firefighter Phone Jack	0	0		x	
B. Future Use	0	0		x	
11. Fire Alarm Interface Devices					
A. Future Use	0	0		x	
B. Maglocks	0	0		x	
C. AHU Shutdown	0	0		x	
D. Door Holders	0	0		x	
E. Roll Down/ Won Doors/ Fire Curtain	0	0		x	
12. Water Flow Switch					
A. Waterflow Switch	1	1	x		
B. Future Use	0	0		x	
13. Supervisory Switch					
A. Valve Tamper	1	1	x		
B. Fire Pump Phase Reversal	0	0		x	
C. Fire Pump Run	0	0		x	
D. Fire Pump Power Fail	0	0		x	
14. Were Tested Detectors Cleaned?	No.			x	
15. Were Detectors Tested For Sensitivity?	No.			x	
16. Did Air Handlers Shut Down As Required?				x	
17. Did Fan Startup operate as required? (Stair pressurization, OAHU, Smoke Evacuation)				x	
18. Did Elevators Recall To The Proper Floors As Required?				x	
19. Did Elevator Shunt Trip Operate As Required?				x	
20. Did the monitoring center receive all required signals?			x		
21. Is system reset for normal conditions?			x		
22. Is system restored to operational service?			x		
23. Have proper authorities (see #1) been notified system is back in service?			x		
24. Indicate % of equip. tested this report	<input type="checkbox"/> 25	<input type="checkbox"/> 50	<input type="checkbox"/> 75	<input checked="" type="checkbox"/> 100	
25. Indicate % of equip. tested YTD	<input type="checkbox"/> 25	<input type="checkbox"/> 50	<input type="checkbox"/> 75	<input checked="" type="checkbox"/> 100	

Comments for any "No" answers or explanations: N/A

# SimplexGrinnell

## BE SAFE.

A business unit of Tyco Fire & Security

### Fire Alarm Equipment Test Report

Task #: 34287694

Equipment	Total Number	Number Tested This Report	Operational		
			Pass	N.A.	Fail
4. Remote Annunciators	0	0		x	
5. Transponders	0	0		x	
6. Booster Panels	0	0		x	
7. Manual Pull Stations	7	7	x		
8. Detectors					
A. Photoelectric	0	0		x	
B. Ionization	0	0		x	
C. Thermal	0	0		x	
D. Flame (UV/IR)	0	0		x	
E. Duct	1	1	x		
F. Beam	0	0		x	
G. CO	0	0		x	
9. Audio/Visuals					
A. Speaker	0	0		x	
B. Speaker/Strobe	0	0		x	
C. Horn	0	0		x	
D. Horn/Strobe	0	0		x	
E. Bell	5	5	x		
F. Bell/Strobe	0	0		x	
G. Chime	1	1	x		
H. Chime/Strobe	0	0		x	
I. Strobe Only	4	4	x		
J. Sounder Base	0	0		x	
K. Remote LED/Light	0	0		x	
10. Fireman's Phones					
A. Firefighter Phone Jack	0	0		x	
B. Future Use	0	0		x	
11. Fire Alarm Interface Devices					
A. Future Use	0	0		x	
B. Maglocks	0	0		x	
C. AHU Shutdown	1	1	x		
D. Door Holders	0	0		x	
E. Roll Down/ Won Doors/ Fire Curtain	0	0		x	
12. Water Flow Switch					
A. Waterflow Switch	1	1	x		
B. Future Use	0	0		x	
13. Supervisory Switch					
A. Valve Tamper	1	1	x		
B. Fire Pump Phase Reversal	0	0		x	
C. Fire Pump Run	0	0		x	
D. Fire Pump Power Fail	0	0		x	
14. Were Tested Detectors Cleaned?	No. 0			x	
15. Were Detectors Tested For Sensitivity?	No. 0			x	
16. Did Air Handlers Shut Down As Required?				x	
17. Did Fan Startup operate as required? (Stair pressurization, OAHU, Smoke Evacuation)				x	
18. Did Elevators Recall To The Proper Floors As Required?				x	
19. Did Elevator Shunt Trip Operate As Required?				x	
20. Did the monitoring center receive all required signals?			x		
21. Is system reset for normal conditions?			x		
22. Is system restored to operational service?			x		
23. Have proper authorities (see #1) been notified system is back in service?			x		
24. Indicate % of equip. tested this report	<input type="checkbox"/> 25	<input type="checkbox"/> 50	<input type="checkbox"/> 75	<input checked="" type="checkbox"/> 100	
25. Indicate % of equip. tested YTD	<input type="checkbox"/> 25	<input type="checkbox"/> 50	<input type="checkbox"/> 75	<input checked="" type="checkbox"/> 100	

Comments for any "No" answers or explanations: N/A

# SimplexGrinnell

**BE SAFE.**
*A business unit of Tyco Fire & Security*

## Fire Alarm Equipment Test Report

SR #: 34287694

Equipment	Total Number	Number Tested This Report	Operational		
			Pass	N.A.	Fail
4. Remote Annunciators	0	0		x	
5. Transponders	0	0		x	
6. Booster Panels	0	0		x	
7. Manual Pull Stations	3	3	x	x	
8. Detectors					
A. Photoelectric	0	0		x	
B. Ionization	14	14	x		
C. Thermal	0	0		x	
D. Flame (UV/IR)	0	0		x	
E. Duct	6	6	x		
F. Beam	0	0		x	
G. CO	0	0		x	
9. Audio/Visuals					
A. Speaker	0	0		x	
B. Speaker/Strobe	0	0		x	
C. Horn	0	0		x	
D. Horn/Strobe	4	4	x	x	
E. Bell	0	0		x	
F. Bell/Strobe	0	0		x	
G. Chime	0	0		x	
H. Chime/Strobe	0	0		x	
I. Strobe Only	2	2	x		
J. Sounder Base	0	0		x	
K. Remote LED/Light	0	0		x	
10. Fireman's Phones					
A. Firefighter Phone Jack	0	0		x	
B. Future Use	0	0		x	
11. Fire Alarm Interface Devices					
A. Future Use	0	0		x	
B. Maglocks	0	0		x	
C. AHU Shutdown	0	0		x	
D. Door Holders	0	0		x	
E. Roll Down/ Won Doors/ Fire Curtain	0	0		x	
12. Water Flow Switch					
A. Waterflow Switch	0	0		x	
B. Future Use	0	0		x	
13. Supervisory Switch					
A. Valve Tamper	0	0		x	
B. Fire Pump Phase Reversal	0	0		x	
C. Fire Pump Run	0	0		x	
D. Fire Pump Power Fail	0	0		x	
14. Were Tested Detectors Cleaned?	No. 0				x
15. Were Detectors Tested For Sensitivity?	No. 0				x
16. Did Air Handlers Shut Down As Required?			x		
17. Did Fan Startup operate as required? (Stair pressurization, OAHU, Smoke Evacuation)				x	
18. Did Elevators Recall To The Proper Floors As Required?				x	
19. Did Elevator Shunt Trip Operate As Required?				x	
20. Did the monitoring center receive all required signals?			x		
21. Is system reset for normal conditions?			x		
22. Is system restored to operational service?			x		
23. Have proper authorities (see #1) been notified system is back in service?			x		
24. Indicate % of equip. tested this report	<input type="checkbox"/> 25	<input type="checkbox"/> 50	<input type="checkbox"/> 75	<input checked="" type="checkbox"/> 100	
25. Indicate % of equip. tested YTD	<input type="checkbox"/> 25	<input type="checkbox"/> 50	<input type="checkbox"/> 75	<input checked="" type="checkbox"/> 100	

Comments for any "No" answers or explanations: N/A