



NOTES:
 AT PIPE CROSSING LOCATIONS, MAINTAIN A MINIMUM 4" VERTICAL CLEARANCES BETWEEN PIPES.
 4" SEWER ISOLATION VALVE BOXES SHALL BE EQUIPPED WITH VALVE POSITION INDICATORS AND DEBRIS SHIELD, TRUMBULL OR SIMILAR

Consultants:

BKI BURK-KLEINPETER, INC.
 ENGINEERS, ARCHITECTS, PLANNERS, ENVIRONMENTAL SCIENTISTS
 4178 CANAL STREET, NEW ORLEANS, LA 70119-3994
 PHONE (504)486-5901 FAX (504)486-1714

Seal:

ROYAL ENGINEERS & CONSULTANTS, LLC
 4298 ELYSIAN FIELDS AVENUE
 NEW ORLEANS, LOUISIANA 70122
 www.royalengineering.net

Approved:

PROGRAM MANAGER, PROJECTS _____
 SAFETY/INDUSTRIAL HYGIENE _____
 HEALTH SYSTEM SPECIALIST _____
 MAINTENANCE SUPERVISOR _____
 MAINTENANCE FOREMAN _____
 MAINTENANCE FOREMAN _____

Drawing Title: **MECH. SITE PLAN**

Approved: Service Engineer _____
 Approved: Service Director _____

Project Title: **VA Gulf Coast Decontamination Unit**

Building Number	Checked	Drawn
XX	MJ	ACM
Location	VAMC BILOXI, MS	

Date: 7/17/2015
 Project No.: 520-13-136
 DRAWING NO.: **M101**
 Dep. Of

FOR CONSTRUCTION

Department of Veterans Affairs