

A
B
C
D
E
F


three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one eighth inch = one foot
one sixteenth inch = one foot

GENERAL SHEET NOTES

1. REFER TO SHEET H-511 FOR MECHANICAL DETAILS.
2. REFER TO SHEET H-611 FOR EQUIPMENT SCHEDULES.

KEYED NOTES



1. EF-2 TO BE MOUNTED 12'-0" A.F.F.
2. UNIT HEATER CONTROLS. VERIFY MOUNTING LOCATION/HEIGHT WITH ARCHITECT.
3. 4-HOUR TWIST TIMER TO OPERATE EXHAUST FAN WHEN SPACE VENTILATION IS DESIRED. REFER TO DETAIL.
4. SIDEWALL EXHAUST FAN PER DETAIL AND EQUIPMENT SCHEDULE. INTERLOCK WITH EVAPORATIVE COOLER.
5. INTAKE LOUVER (2.97 SQ. FT. FREE AREA) WITH MOTORIZED DAMPER. INTERLOCK WITH EF-1, EF-2, AND EF-3. MOUNT 12'-0" A.F.F.
6. UNIT HEATER PER EQUIPMENT SCHEDULE. INSTALL UNIT WITH ALL REQUIRED SERVICE AND OPERATIONAL CLEARANCES, INCLUDING ALL REQUIRED CLEARANCES TO COMBUSTIBLES. MOUNT UNIT 10'-0" A.F.F. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT OF UNIT HEATER WITH ARCHITECT PRIOR TO INSTALLATION.
7. 24/16 TRANSFER GRILLE 12'-0" A.F.F. COORDINATE LOCATION WITH ARCHITECT.
8. 4" VENT AND 4" COMBUSTION AIR DUCT TO AGA APPROVED FACTORY-PROVIDED CONCENTRIC TERMINAL THROUGH ROOF. VENT AND COMBUSTION AIR DUCT SHALL BE CONSTRUCTED OF MATERIALS REQUIRED BY UNIT HEATER MANUFACTURER. INSTALL VENT AS NECESSARY TO PROVIDE ALL REQUIRED CLEARANCES TO COMBUSTIBLE MATERIALS. AND INSTALL CONCENTRIC TERMINAL PER MANUFACTURER'S REQUIREMENTS.
9. EF-1, ABOVE, TO BE MOUNTED 12'-0" A.F.F. AND EF-3, BELOW, TO BE MOUNTED 2'-0" A.F.F.



E3 STORAGE BUILDING MECHANICAL FLOOR PLAN

SCALE: 1/4" = 1'-0"

IN THE EVENT THAT BONES OR HISTORIC ARCHEOLOGICAL MATERIAL ARE UNCOVERED DURING CONSTRUCTION OR EARTH DISTURBING ACTIVITIES, CEASE WORK IMMEDIATELY AND PROTECT THE REMAINS FROM FURTHER DISTURBANCE. NOTIFY THE OWNER, THE DIRECTOR OF FORT BLISS NATIONAL CEMETERY AT AT 915-564-0201. THE OWNER WILL CONTACT THE NEW MEXICO HISTORIC PRESERVATION DIVISION (SHIPD). THE OWNER AND SHIPD MAY DISCUSS THE APPROPRIATE WAY TO PROCEED. DIRECTION TO THE CONTRACTOR WILL BE PROVIDED BY THE OWNER.



100% CONSTRUCTION DRAWINGS

SUB-CONSULTANTS		PRIME CONSULTANT		Drawing Title	Project Title	Project Number	NATIONAL CEMETERY ADMINISTRATION	
				STORAGE BUILDING MECHANICAL FLOOR PLAN	CEMETERY IMPROVEMENTS AND NEW MAINTENANCE BUILDING	885CM3007	OFFICE OF DESIGN AND CONSTRUCTION	
210 La Veta NE, Albuquerque, NM 87108 505.268.2256 FAX 505.265.9637 1311 W. WILSON BLVD., SUITE 100 ALBUQUERQUE, NM 87102		2020 K STREET, SUITE 300 WASHINGTON, DC 20006 TELEPHONE: (202)872-0277 FAX: (202)872-0282.		Approved: Director Office of Construction Management	Location FORT BAYARD, NEW MEXICO	Building Number BLDG #2	Department of Veterans Affairs	
Revisions:		10182			Date NOVEMBER 18, 2011	Checked RA	Drawn NJS	Dwg. 107 of 120