

REQUEST FOR INFORMATION FORM

**SOLICITATION NO. VA245-16-B-0049
PROJECT 688-645
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC**

Submitted By: (Include full name, address and phone number of company) Date: 19 July 2016

Ribeiro Construction Co., Inc.; 7385-A Old Alexander Ferry Road, Clinton, MD 20735; 301.877.1396

Point of Contact: Cindy Bladen

Reference/Subject: Precast Architectural Concrete

Spec. Section No./Title: _____

Page/Art./Para. _____

Drawing No.: _____

Plan/Detail/Schedule: _____

Question: (Explain in detail)

Please provide the Precast Architectural concrete mix and finish used on the Phase One portion of the deck.

Response:

- a. The Precast Architectural Concrete Mix and finish used will be provided to the winning bidder.
- b. The winning contractor is required to Provide samples to match the existing Precast Architectural Concrete Finish.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 19, 2016.