

# **REQUEST FOR INFORMATION FORM**

**SOLICITATION NO. VA245-16-B-0049  
PROJECT 688-645  
EXPAND VISITOR/ PATIENT PARKING GARAGE  
VAMC WASHINGTON, DC**

**Submitted By: (Include full name, address and phone number of company) Date:** 19 July 2016

Ribeiro Construction Co., Inc.; 7385-A Old Alexander Ferry Road, Clinton, MD 20735; 301.877.1396

**Point of Contact:** Cindy Bladen

**Reference/Subject:** PCI-116 & PCI-117

**Spec. Section No./Title:** 03 45 00-Precast Arch Concrete **Page/Art./Para.** \_\_\_\_\_

**Drawing No.:** \_\_\_\_\_ **Plan/Detail/Schedule:** \_\_\_\_\_

---

**Question: (Explain in detail)**

It is respectfully noted the Precast Manufacturers have acknowledged PCI-116 but all have excluded PCI-117. Please clarify the intent of the VA for inclusion of PCI-117 in the RFP and will the PCI-116 be acceptable to the Government in place of PCI-117?

---

**Response:**

PCI-117 was a requirement in the specifications for the base garage design and construction. Therefore, the intent for the phase 1 expansion is to comply with the same standards, unless authorized otherwise by the VA.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, [Robert.perry2@va.gov](mailto:Robert.perry2@va.gov) OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 19, 2016.