

REQUEST FOR INFORMATION FORM

**SOLICITATION NO. VA245-16-B-0049
PROJECT 688-645
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC**

Submitted By: (Include full name, address and phone number of company) Date: 19 July 2016

Ribeiro Construction Co., Inc.; 7385-A Old Alexander Ferry Road, Clinton, MD 20735; 301.877.1396

Point of Contact: Cindy Bladen

Reference/Subject: Lighting Control Sequence Design

Spec. Section No./Title: _____ **Page/Art./Para.** _____

Drawing No.: _____ **Plan/Detail/Schedule:** _____

Question: (Explain in detail)

Please specify product info used for the bases of the intended LIGHTING CONTROL SEQUENCE design.

Response:

Lumark LED fixture as indicated in schedule with Thomas Research Step Dimming Module, or Lutron Module, to provide dimming to 30% as indicated in Control Sequence. Occupancy sensor controls could be one of several manufacturers such as Lithonia, Leviton, or Watt Stopper. Ditto for daylight sensors.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 19, 2016.