



D
DENOTES SPAN DIRECTION OF
3" COMPOSITE STEEL DECK W/
2" CONCRETE (5" TOTAL
THICKNESS). REINF. SLAB
W/ 6x6-W2.1xW2.1 W.W.F.

DENOTES BEAM SIZE W16x26



UPLIFT WIND PRESSURES	
ZONE	PRESSURE *
1	-41.7 PSF
2	-65.7 PSF
3	-89.7 PSF

* BASED ON TRIBUTARY AREA
= 16 SQUARE FEET.

VA FORM 08-6231A, MAR 1984

PADGETT
Engineering Group
Consulting Structural Engineers

2255 CUMBERLAND PARKWAY - SUITE 1910 - ATLANTA - GEORGIA 30333



TOLAND
MIZELL
MOLNAR

590 Means Street NW, Suite 200
Atlanta, GA 30318
404.214.9774

MACHINE ROOM & TOWER
ROOF FRAMING PLANS

Approved: Project Director

EXPAND RADIOLOGY AND SPS
OVERTON BROOKS VAMC

Check	
-------	--

Draw

11

[illegible]

667-083

Building Number
1

Drawing Number:

S104

Days of YY

Dwg.	01 XX
------	-------

OFFICE OF
CONSTRUCTION
AND FACILITIES
MANAGEMENT

