

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	N/A	RFI NO.:	001
PROJECT NAME:	INSTALL New Medical Air System	DATE REQUESTED:	
SOLICITATION NO.:	VA262-16-Q-1075	REFERENCE:	
DRAWING:	N/A	SPECIFICATION SECTION:	N/A
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
<p>Please be specific as possible:</p> <p>There are two (2) additional pipe connected to the main medical air copper piping. One pipe is small; approximately 1/2" diameter. The other is on a separate regulator SE at 80 psig; approximately 1" diameter. Please confirm that the two (2) pipes are medical air applications per NFPA 99-2012. If these pipes are medical air applications, the 1" copper piping will be set for 55 psig per NFPA 99-2012 after construction. Two (2) photos are included with this RFI.</p>			
PROJECT MANAGER'S RESPONSE			
<p>The 1/2" diameter line goes to the Plants control board for system pressure monitoring. The 1" line is medical air and will be okay set to 55 psi.</p>			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: Thurston Ford, Structural Supervisor		DATE: August 4, 2016	