



Alexandria Office
120 17th Avenue W.
Alexandria, MN 56308
(320) 762-1290

St. Cloud Office
3339 West St. Germain, Suite 250
St. Cloud, MN 56301
(320) 217-5557

**AMENDMENT NO. 1
MAY 25, 2016**

PROJECT: Remodel Site for Upgraded CT Scanner

This addendum shall be added to and become a part of the original plans and specifications. All items shall be as originally specified or drawn, unless specifically amended by this or subsequent addenda. Receipt of this addendum must be acknowledged on bid form.

PROJECT MANUAL CHANGES:

None

DRAWING CHANGES:

1. Drawing E4.1
 - A. Revise General Note #4 to read as follows:
UPS bypass (1) and battery cabinet (1) is to be supplied with the CT scanner equipment which will be supplied under a different contract. UPS bypass (2) and battery cabinet (2) to be provided under this contract. Both UPS and bypass units are to be installed by contractor under this contract. All conduit and wiring to the ups and bypass units are to be provided under this contract.
 - B. Add General Note #5 to read as follows:
Contractor will be required to be on site when the Government's CT scanner supplier is on site installing the CT equipment. Contractor shall coordinate the CT scanner supplier schedule and power up of the CT Scanner UPS (1) and Bypass cabinet (1) with the COR. UPS (1) and Bypass cabinet (1) shall not be powered up until prior notice from the COR has been provided.

CLARIFICATIONS:

None

ATTACHMENTS:

None

END OF ADDENDUM

MECHANICAL

ELECTRICAL

STRUCTURAL

CIVIL

LAND SURVEYING