

REQUEST FOR INFORMATION (RFI)**VA251-16-B-0036**

PROJECT NUMBER:	655-14-101	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Bldg. 1 Renovation	
PROJECT LOCATION:	Department of Veterans Affairs Aleda E. Lutz VA Medical Center 1500 Weiss Street Saginaw, MI 48602	

SUBMITTED BY:		City/State:	
PHONE NO.:			

TO: Contracting Specialist Sonny S. Earls
Sonny.Earls@va.gov

RFI NO.:	DATE:8/8/16	REFERENCE:
REPLY NEEDED BY:		

INFORMATION NEEDED:

Is a signage schedule included in the documents? One is required to determine the signage which is to be provided.

REPLY:

Specification **10-14-00** provides color, size, finish, font, etc.

Drawing **1-AD1.1** provides pictorial examples of signs that will be removed and replaced during the course of the project.

1-A9.1.1 – 1.A9.4 provides “**equipment plan abbreviations**” explaining contractor responsibility for providing signage. Included in these drawings are the general locations that new signage is required.

1-F0.1 – 1-F0.2 provides finish schedules including guidance for signage locations, room numbers, room names, etc.

REPLY FROM: Robert Peters	DATE: 8/8/2016
ATTACHMENTS:	COPY TO: