



Revisions	Date
1. RESPONSE TO RFI #001	08-29-16

- KEYNOTES-VOICE/DATA**
1. PROVIDE 19" [483mm] EQUIPMENT RACKS, 7' [2134mm] IN HEIGHT.
 2. ELECTRICAL RECEPTACLES, RACK OR CABINET MOUNTED PROVIDED BY ELECTRICAL CONTRACTOR, COORDINATE INSTALLATION REQUIREMENTS.
 3. 3/4" [19mm] x 8" HIGH PLYWOOD BACKBOARD ON ALL WALLS, 2 COATS OF FIRE RETARDANT PAINT ALL SIDES, MOUNT BOTTOM EDGE AT 20" AFF.
 4. PROVIDE 12" [305mm] LADDER RACK MOUNTED AT 7'-3" [2210mm] AFF.
 5. GROUNDING BUS BAR.
 6. PROVIDE 4" [102mm] VERTICAL CONDUIT SLEEVES, UP AND DOWN EXCEPT 1ST (UP ONLY) AND 4TH (DOWN ONLY) FLOORS.
 7. PROPOSED LOCATION FOR VOICE CROSS CONNECT FIELD MOUNTED 36" AFF TO BOTTOM, VERIFY WITH QNWR.

M. Moncef Hadji, P.E.
Florida License #48022

06/20/2016

TLC
ENGINEERING
FOR ARCHITECTURE
874 Dixon Boulevard
Cocoa, FL 32922
Phone: 321-634-0274
Fax: 321-639-8986
www.tlc-engineers.com
© Copyright 2016 TLC Engineering for Architecture, Inc.
COA #15 TLC NO: 515172

mri
FL LIC #AA000284
ARCHITECTURAL GROUP, INC.
5032 GODDARD AVENUE
ORLANDO, FLORIDA 32804
(407) 245-3660
ORLANDO@mriarchitects.com
PETER M. IKEGAMI FL LIC #AR13065

Drawing Title
ENLARGED TECHNOLOGY PLAN

Project Title
**RENOVATE BUILDING 2
(Interiors and Systems)
RESEARCH (FCA-D)**

Approved: Project Section Chief
James Dahnke

Approved: Division Chief
James A. Blatchley

Approved: Facility Director
Joe D. Battle

Location
**JAMES A. HALEY VETERANS' HOSPITAL
13000 BRUCE B. DOWNS BLVD.
TAMPA, FLORIDA 33612**

Drawn
DRS
Date
JUNE 23, 2016

Checked
MMH
Project No.
673-11-114

Bldg #
2
DRAWORD NO.
2-T401

VA File Number

Dwg. Of

