

1
2-EP101 | 2-FA100 1/8" = 1'-0"

BASEMENT — FIRE ALARM

GENERAL FIRE ALARM NOTES

1 REFER TO ARCHITECTURAL ELEVATIONS FOR FINAL MOUNTING HEIGHTS OF ALL DEVICES. UNLESS NOTES OTHERWISE, ARCHITECTURAL ELEVATIONS SHALL DICTATE MOUNTING HEIGHTS OF ALL FIXTURES.

2 VERIFY AND COORDINATE EXACT ELECTRICAL REQUIREMENTS OF ALL EQUIPMENT WITH MANUFACTURER'S RECOMMENDATIONS PRIOR TO INSTALLATION OF EQUIPMENT.

3 REFER TO SYSTEM RISER DIAGRAMS AND DETAILS FOR ADDITIONAL INFORMATION.

4 TEMPORARY HEAT DETECTORS SHALL BE INSTALLED THROUGHOUT THE FACILITY DURING CONSTRUCTION IN ACCORDANCE WITH NFPA 72.

KEYNOTES- FIRE ALARM

1 PROVIDE ALL FIRE SPRINKLER FLOW AND/OR TAMPER SWITCHES WITH ADDRESSABLE CONNECTION TO FIRE ALARM SYSTEM. CONNECT TO ADDRESSABLE SLC CIRCUIT WITHIN THE SAME SMOKE COMPARTMENT.

Revisions	Date
1 RESPONSE TO RFI #001	08-29-16

M. Moncef Hadji, P.E.
Florida License #48022

06/20/2016

TLC
ENGINEERING
FOR ARCHITECTURE

874 Dixon Boulevard
Cocoa, FL 32922
Phone: 321-434-0274
Fax: 321-439-8986
www.tlc-engineers.com
© Copyright 2016 TLC Engineering for Architecture, Inc.
COA #15 TLC NO: 515172

mri
FL LIC #AA000284

ARCHITECTURAL GROUP, INC.

5032 GODDARD AVENUE
ORLANDO, FLORIDA 32804
(407) 245-3660
ORLANDO@mriarchitects.com
PETER M. IKEGAMI FL LIC #AR13065

Drawing Title

BASEMENT - FIRE ALARM

Project Title

RENOVATE BUILDING 2
(Interiors and Systems)
RESEARCH (FCA-D)

Approved: Project Section Chief
James Dahnke

Approved: Division Chief
James A. Blatchley

Approved: Facility Director
Joe D. Battle

Location JAMES A. HALEY VETERANS' HOSPITAL
13000 BRUCE B. DOWNS BLVD.
TAMPA, FLORIDA 33612

Drawn DRS Date JUNE 23, 2016

Checked MMH Project No. 673-11-114

Bldg # 2 DRAWING NO. 2-FA100

VA File Number Dwg. Of

Office of Facilities
Department of Veterans Affairs