

- 1 HRMS, CREDIT UNION  
2 LAB, TRAVEL, AGENT CASHIER  
3 NURSING UNITS  
3A LAB, RAD, DIR SUITE  
4A PRIM CARE, POD, MED LIB  
5 DIETETICS  
6 VACANT  
7 VACANT  
8 ENGINEERING, TAHEC  
9 A&MM, FISCAL  
10 BOILER PLANT  
11 ENGINEERING SHOPS  
12 ENGINEERING SHOPS  
13 FIRE STATION  
14 SECURITY, PSYCHOLOGY  
15 VACANT  
16 HOUSEKEEPING QUARTERS  
17-20 NON-HOUSEKEEPING QTRS  
21 CHLORINATOR HOUSE  
22 PSYCHIATRY  
23 OIL STORAGE RESERVOIR  
24 VACANT  
25 STORAGE  
26 WATER TANK TOWER  
27 GARAGE  
28 GARAGE  
29 PTSD, DOM, DAY TREATMENT  
30 DIRECTOR'S QUARTERS  
31 LAUNDRY  
32 PSYCHIATRY  
33 PSYCHIATRY  
34 GRANDSTAND  
35 WATER TANK TOWER  
36 AMBULATORY CARE  
37 WAREHOUSE  
38 CANTEN, RECREATION, VOL  
39 MECHANICAL EQUIPMENT  
40 CHAPEL  
41 PAVILION  
42 CHILLER PLANT  
43 GREENHOUSE  
44 COOLING TOWER  
T-101 PAINT STORAGE  
120 INTERMEDIATE CARE  
121 EMERGENCY GENERATOR  
122 EMERGENCY GENERATOR  
123 EMERGENCY GENERATOR  
124 EMERGENCY GENERATOR  
125 NURSING HOME

NEW GAS NOTES (CONT)

- (J) 1-1/4" TO BLDG 5 W/CUTOFF VALVE AT EXIST 1-1/4" MAIN  
(K) 1-1/4" TO BLDG 2 W/CUTOFF VALVE AT 2" MAIN  
(L) 1-1/2" TO BLDG 4A W/CUTOFF VALVE AT 2" MAIN  
(M) 2" TO BLDG 2/4A W/CUTOFF VALVE AT 2-1/2" MAIN  
(N) 1-1/2" TO BLDG 6B W/CUTOFF VALVE AT 2-1/2" MAIN  
(P) 2-1/2" TO BLDG 2/4A/6B W/CUTOFF VALVE AT EXIST 8" MAIN  
(Q) 1" TO BLDG 13 W/CUTOFF VALVE AT EXIST 8" MAIN  
(R) 1" TO BLDG 14/15 W/CUTOFF VALVE AT EXIST 8" MAIN  
(S) 1" TO BLDG 8B W/CUTOFF VALVE AT EXIST 1-1/4" MAIN

CONNECT NEW 1-1/2" GAS LINE TO EXISTING 1-1/2" GAS SERVICE. FIELD VERIFY EXIST SIZE AND LOCATION.  
ALL ROOF PIPING SHALL BE INSTALLED ON MILD STEEL OR APPROVED EQUIVALENT. PIPE STANDS-PIN, PAINT, AND LABEL ALL EXPOSED GAS PIPING.  
FURNISH AND INSTALL COPPER B-LINE PIPE, BRACKET B3088-1 OR APPROVED EQUAL ON 6 FOOT CENTERS (ANCHORED TO WALL, PRIME AND PAINT TO MATCH BUILDING EXTERIOR).  
NEW GAS REGULATOR, DEMAND = 4700 MBH, PRESSURE = 2 P.S.I., LONGEST RUN (REF.) = 70', COORDINATE WITH LOCAL UTILITY, PAY ALL COSTS, FEES, ETC.  
NEW 1-1/2" GAS LINE DOWN IN AIRWAY TO BOILERS IN MECHANICAL ROOM.  
INSTALL GAS PRESSURE ON ROOF FOR GWH-2, 200 MBH, 1-1/4" S.  
DOWN EXTERIOR WALL INTO BUILDING AS HIGH AS POSSIBLE TO GWH-2.

- NEW GAS NOTES  
(A) CONNECT NEW 2-1/2" TO EXIST 6"  
(B) ROUTE 1-1/2" TO BLDG 120 W/SHUTOFF VALVE AT CONNECTION TO 2-1/2" MAIN  
(C) 1-1/2" TO BLDG 120/3A W/ CUTOFF VALVE AT 2-1/2" MAIN  
(D) 2" TO BLDG 83/62 W/CUTOFF VALVE AT 2-1/2" MAIN  
(E) 1-1/2" TO BLDG 83 W/CUTOFF AT 2" MAIN  
(F) 1-1/2" TO BLDG 62 W/CUTOFF AT 2" MAIN  
(G) 1" TO BLDG 3A W/ CUTOFF AT 1-1/2" MAIN  
(H) 1-1/2" TO BLDG 120 W/CUTOFF VALVE AT 1-1/2" MAIN

PLUMBING SITE PLAN - BUILDING 90  
SCALE: 3/32"=1'-0"

PLUMBING DRAWING INDEX


SHEET NO.	SHEET TITLE
90P1.1	PLUMBING SITE PLAN - BUILDING 90
90P2.1	PLUMBING SCHEDULES, NOTES, LEGEND, DETAILS AND BASEMENT DEMOLITION PLAN - BUILDING 90
90P2.2	REVISED PLUMBING PLAN - BUILDING 90
90P2.3	EXISTING PLUMBING PLAN AND DETAILS - BUILDING 90
90P2.4	EXISTING PLUMBING DETAILS - BUILDING 90

WHORTON ENGINEERING, INC.  
HVAC - PLUMBING - PROCESS CONTROL

RANDALL WHORTON, P.E.  
PH 256/820-9897 FAX 256/820-9896  
25 SUMMERALL GATE ROAD  
ANNISTON, ALABAMA 36205

ALABAMA  
REGISTERED  
PROFESSIONAL  
ENGINEER  
No. 14192  
R. D. WHORTON

WHORTON ENGINEERING PROJECT NO. 10159



**MCE MILLS-CONOLY**  
ENGINEERING, P.C.  
8218 Old Federal Road  
TELEPHONE: (334) 270-0010  
Montgomery, AL 36117  
FAX: (334) 270-0040



Approved:	Approved:	Drawing Title	Project Title	Date
Approved:	Approved:	PLUMBING SITE PLAN - BUILDING 90	HVAC MODIFICATIONS TO BUILDINGS 83, 90, & 93 TUSKEGEE, ALABAMA	12/21/10
Approved:	Approved:	Safety Officer	Building Number 90	Project No. 619-10-445
Approved:	Approved:	Clinical Representative	Checked RDW	Drawn JAD
			Location East Campus, Tuskegee, AL	DRAWING NO. 90P1.1 Dwg. 40 of 59

Veterans Administration