

The following documents have been revised (updated). These documents shall be incorporated in Solicitation: VA250-16-B-0523 "Upgrade Emergency Fuel Oil Transfer".

### **Mechanical Items**

#### **DRAWINGS**

ITEM 1      1-M3.0

1. Modified notes - Control Panel for Fuel Oil Pump Sets.
2. Added audible alarm points to Fuel Oil Pump Package Schedule.
3. Added notes for control panel indicator lights – Fuel Oil Pump Piping Connection Detail.

ITEM 2      1-M5.0

1. Added existing to remain points and existing to be removed points for Generators (1-4) day tanks and Generator 5 day tank.
2. Added a point for emergency stop to each new fuel oil pump package.
3. Modified notes for Fuel Oil Alarm Panel.