

Red Hawk Fire and Security
7020 Fly Road
East Syracuse, NY 13057
Tel 315-458-1154 Fax 315-458-8223

REQUEST FOR INFORMATION

Subcontractor: Red Hawk Fire and Security

RFI Number: 001

Date: **September 6**

From: Kevin Beals

RFI Description:

Spec. Section: **Fire Alarm : Section 28 08 00**

Drawing Number:

Other Reference: **Drawing FA-001 General Fire Alarm Notes #14**

Question: The note describes a complete test.
Does this require: 1) A full system test (approx. 160 labor hours) or
2) Testing only of the renovated area plus 10% per
NFPA (approx. 12 labor hours)

#2 is correct. Only test the part of the system being renovated, not the entire system.