

## Norman, Keith A. VISN6 CAS

---

**From:** Fine, Benjamin L SBYVAMC  
**Sent:** Thursday, February 23, 2012 1:23 PM  
**To:** Norman, Keith A. VISN6 CAS  
**Subject:** RE: Question - Sol # VA24612B0789

### Answer :

01 91 00

#### 1.1 DESCRIPTION

A. This Section 01 91 00 GENERAL COMMISSIONING REQUIREMENTS shall form the basis of the construction phase commissioning process and procedures. The Commissioning Agent shall add, modify, and refine the commissioning procedures, as approved by the Department of Veterans Affairs (VA), to suit field conditions and actual manufacturer's equipment, incorporate test data and procedure results, and provide detailed scheduling for all commissioning tasks.

E. Commissioning is a systematic process of verifying that the building systems perform interactively according to the construction documents and the VA's operational needs.

#### SECTION 23 08 00 COMMISSIONING OF HVAC SYSTEM

#### 1.6 SUBMITTALS

- A. The commissioning process requires review of selected Submittals. The Commissioning Agent will provide a list of submittals that will be reviewed by the Commissioning Agent. This list will be reviewed and approved by the VA prior to forwarding to the Contractor. Refer to Section 01 33 23 SHOP DRAWINGS, PRODUCT DATA, and SAMPLES for further details.
- B. The commissioning process requires Submittal review simultaneously with engineering review. Specific submittal requirements related to the commissioning process are specified in Section 01 91 00 GENERAL COMMISSIONING REQUIREMENTS.

#### FOR CLARIFICATION:

A Commissioning Agent (CxA) is to be submitted to the Department of Veterans Affairs for approval to conduct commissioning process.

For items to be commission refer to Construction Drawings **M-101 & M-102**.  
What is the need of the Government.....**An Isolation Room**

---

**From:** Norman, Keith A. VISN6 CAS  
**Sent:** Wednesday, February 22, 2012 2:27 PM  
**To:** Fine, Benjamin L SBYVAMC  
**Subject:** FW: Question - Sol # VA24612B0789

Please advice to the below question.

*Keith Norman*  
*Contract Specialist*  
*VA Medical Center - Supply Bldg. #27*  
*Hampton, VA 23667*  
*Phone: 757-315-3958*  
*Fax: 757-728-3132*  
*Email: [Keith.Norman2@va.gov](mailto:Keith.Norman2@va.gov)*

---

**From:** Jeremy Stansell [<mailto:jeremy@daykoservices.com>]  
**Sent:** Wednesday, February 22, 2012 2:24 PM  
**To:** Norman, Keith A. VISN6 CAS  
**Cc:** 'Eric Tyson'  
**Subject:** Question - Sol # VA24612B0789

## Y--Isolation & Bariatric Room Bldg 2 FL 3

Agency: Department of Veterans Affairs

Office: Hampton VAMC

Location: Department of Veterans Affairs Medical Center

Question: Amendment 1 of Solicitation Number: VA24612B0789 includes specifications for general commissioning and commissioning of HVAC systems. Could you please explain the exact commissioning requirements for this project? The specifications seem too general and the requirement for commissioning is not clear.

Thanks.

Jeremy Stansell  
PO Box 119  
1501 Walker Church Rd  
Greensboro, GA 30642  
706-453-1849 office  
706-453-1850 fax  
706-252-4566 cell phone  
[www.daykoservices.com](http://www.daykoservices.com)