

Norman, Keith A. VISN6 CAS

From: Fine, Benjamin L SBYVAMC
Sent: Friday, February 17, 2012 9:06 AM
To: Norman, Keith A. VISN6 CAS
Subject: RE: VA Bid Solicitation Number:VA24612B0789 Questions

Answers

Is there a Spec for the ceiling lift? **NO**

Please confirm that there is only one Bariatric room - **YES, ONLY 5051A-**

What are going to be the following dimensions?

- Floor to acoustical ceiling tile- **8"-0" + or - 1"**
- Acoustical ceiling tile to the deck?- **25"-30" see Joist & slab schedule**
- Is there a floor above this room? **YES-THE FOURTH FLOOR**
- What is the deck made of? Concrete with metal pan? Concrete? What is the thickness of the deck? **DECK IS CONCRETE WITH REINFORCEMENT- see Joist & Slab schedule**
- What is there a weight capacity for the Bariatric Lift?-**750lbs- 1000lbs-**

JOIST & SLAB SCHEDULE						
MARK	JOIST		REINFORCING		TOP BARS	LOCATION OF TOP BARS
	D	D	BOTTOM BARS			
			STRAIGHT	BENT		
51	5"	6" + 2 1/2"	1 - 3/8" ϕ	1 - 3/8" ϕ		NOTE: STRAIGHT BAR TO EXTEND 2'-0" BEYOND REAR FACE OF INTERIOR DEAM.

From: Norman, Keith A. VISN6 CAS
Sent: Friday, February 17, 2012 7:22 AM
To: Fine, Benjamin L SBYVAMC
Subject: VA Bid Solicitation Number:VA24612B0789 Questions

FYI please see questions below. When you have the answers please send them to me so that I can get them posted ASAP.

Thank you!!!

Keith Norman
Contract Specialist
VA Medical Center - Supply Bldg. #27
Hampton, VA 23667
Phone: 757-315-3958
Fax: 757-728-3132
Email: Keith.Norman2@va.gov

From: Tracey Harrill [<mailto:tharrill@midatlanticare.com>]
Sent: Wednesday, February 15, 2012 9:51 PM
To: Norman, Keith A. VISN6 CAS
Subject: VA Bid Solicitation Number:VA24612B0789

Mr. Norman,

I am writing to submit questions regarding the following bid:

Is there a Spec for the ceiling lift?

Please confirm that there is only one Bariatric room - 3051A.

What are going to be the following dimensions?

- Floor to acoustical ceiling tile
- Acoustical ceiling tile to the deck?
- Is there a floor above this room?
- What is the deck made of? Concrete with metal pan? Concrete? What is the thickness of the deck?

What is there a weight capacity for the Bariatric Lift?

Thank you.

Tracey

Tracey Harrill, R.N.
Safety Consultant - The Carolina's

Mid-AtlantiCare

P.O. Box 444 - 3123 Riva Road

Riva, MD 21140

Cell: 704-900-4323

Main: 410-956-8171 Fax: 888-588-1646

Email: tharrill@midatlanticare.com

Web: www.midatlanticare.com

Delivering Patient Handling Solutions

**Newark - Philadelphia - Baltimore - Richmond -
The Carolina's**