

**DEMOLITION NOTES:**


1. DETAILED AND MAINTAINED SCHEDULE IS REQUIRED AND MUST BE COORDINATED WITH VA MC.
2. DRAWING IS CONCEPT ONLY. ALL DIMENSIONS AND EXISTING CONDITIONS MUST BE FIELD VERIFIED.
3. DEMOLITION TO TAKE PLACE 30 DAYS AFTER NEW EQUIPMENT IS PUT INTO SERVICE.
- SECOND SHUTDOWN SWITCH FROM EXISTING SYSTEM TO NEW SYSTEM
4. CONTRACTOR TO DISCONNECT FEEDER FROM NEW CONTROL PANEL AT TEMPORARY SPARE BREAKER AND TERMINATE FEEDER TO THE NEWLY INSTALLED BREAKER.
5. ISOLATE OLD DENTAL EVAC SYSTEM FROM NEW DENTAL EVAC SYSTEM USING BLOCK VALVES, BLINDS AND PLUGS.
6. DISCONNECT AND DISPOSE OF UNNECESSARY PIPE.
7. DISCONNECT AND DISPOSE OF UNNECESSARY WIRE AND CONDUIT.
8. REMOVE AND RETURN TEMPORARY SPARE BREAKER TO VA MC.
9. DEMOLISH AND DISPOSE OF ONE (1) 4-INCH THICK HOUSEKEEPING PAD. REMOVE RESIDUAL ADHESIVE.
10. REMOVE PINS AND REPAIR CONCRETE AT HOUSEKEEPING PAD LOCATION.
11. REMOVE AND RETURN TWO (2) BLDGERS TO VA MC.
12. REMOVE AND RETURN CONTROL PANEL TO VA MC.
13. DEMOLISH AND DISPOSE OF TWO (2) 24-INCH VET SEPARATORS.
14. CONTRACTOR IS RESPONSIBLE FOR REMOVING ALL DEBRIS FROM WORK AREA. VA DUMPSTERS MAY BE USED.

**COLOR KEY**  
 EXISTING ———  
 DEMOLITION ———  
 NEW ———

DEMO

MECHANICAL EQUIPMENT ROOM LL528  
 MECHANICAL SYSTEM RISER No. 0010

Revision	Description



Drawing Title <b>DEMOLITION PLAN</b> Scale: 1/4"=1'-0" Approved: Chief Engineer	Project Title <b>FCA REPLACE DENTAL EVAC</b>	Date <b>3/7/2011</b> Project No. <b>553-11-120</b> Building Number <b>100</b> Location <b>Detroit, Michigan</b>	Drawn <b>LK</b> SHEET <b>4</b> Dep. of <b>Veterans Affairs</b>
--	---	--	--