



FEEDWATER PUMP SCHEDULE									
UNIT NO.	LOCATION	GPM	DISCHARGE (PSI)	MOTOR HP	HEAD (PSI)	HEAD (FT)	VOLTS	PHASE	REMARKS
BFP-1	FIRING FLOOR	25	120	15	120	280	460	3	BASED ON GRUNDFOS MODEL CRN
BFP-2	FIRING FLOOR	25	120	15	120	280	460	3	BASED ON GRUNDFOS MODEL CRN
BFP-3	FIRING FLOOR	25	120	15	120	280	460	3	BASED ON GRUNDFOS MODEL CRN

[illegible]

DEAERATOR SCHEDULE									
UNIT NO.	LOCATION	CAPACITY (GALLONS)	TANK DIAMETER (INCHES)	TANK LENGTH (INCHES)	RATING (LBS/HR)	CONFIGURATION	OPERATING (LBS)	STORAGE CAPACITY (MINUTES)	REMARKS
DA-1	MEZZANINE	600	54	118	20,000	HORIZONTAL	12,050	10	BASED ON CLEAVER BROOKS MODEL NUMBER SM-30

SURGE TANK SCHEDULE							
UNIT NO.	LOCATION	CAPACITY (GALLONS)	TANK DIAMETER (INCHES)	TANK LENGTH (INCHES)	CONFIGURATION	OPERATING WEIGHT (LBS)	REMARKS
ST-1	MEZZANINE	1400	60	125	HORIZONTAL	14,500	BASED ON CLEAVER BROOKS MODEL NUMBER SRG-1400

[illegible][illegible][illegible]