


FEEDER SCHEDULE							
FEEDER NO	CONDUIT	CONDUCTORS NO & SIZE	INSULATION TYPE	GROUND CONDUCTOR	FEEDER ORIGIN	FEEDER TERMINATION	NOTES
1	(2)3"PVC	(3)350 KCMIL	THWN	N/A	TRANSFORMER	BLDG 5 DISC.	
1a	(2)3"EMT	(3)350 KCMIL	THWN	(1)#1	BLDG 5 DISC.	PANEL MDP5	
2	1-1/2"	(3)#2	THHN	(1)#8	PANEL MDP5	PANEL 5C	
3	1-1/2" EMT	(3)#1/0	THWN	(1)#6	PANEL MDP5	PANEL 5B	
4	1-1/2" EMT	(3)#1/0	THWN	(1)#6	PANEL MDP5	PANEL 5A	
5	1-1/2"	(3)#1	THWN	N/A	PANEL MDP5	(E)J-BOX	
5a	1-1/2"	(3)#1	TW	N/A	(E)J-BOX	BLDG 26	
6	2" EMT	(3)#3/0	THWN	N/A	PANEL MDP5	PB52	
6a	2" PVC	(3)#3/0	THWN	N/A	PB52	PB61	
6b	2" EMT	(3)#3/0	THWN	N/A	PB61	PANEL 6A	
7	2-1/2" EMT	(3)#4/0	THWN	N/A	PANEL MDP5	PB52	
7a	3" PVC	(3)#4/0	THWN	N/A	PB52	PB71	
7b	2-1/2" EMT	(3)#4/0	THWN	N/A	PB71	PANEL 7A	
8	2-1/2" EMT	(3)250 KCMIL	THWN	N/A	PANEL MDP5	PB52	
8a	3" PVC	(3)250 KCMIL	THWN	N/A	PB52	PB81	
8b	2-1/2" EMT	(3)250 KCMIL	THWN	N/A	PB81	PANEL 8A	
9	3" PVC	(3)500 KCMIL	THWN	N/A	TRANSFORMER	BLDG 4 DISC.	
9a	3" EMT	(3)500 KCMIL	THWN	(1)#2	BLDG 4 DISC.	PANEL 4A	
10	1-1/2" EMT	(3)#1/0	THWN	(1)#6	PANEL 4A	PANEL 4B	

2 BUILDING 6 FEEDER SCHEDULE  
SCALE: NONE



1 BUILDING 6 POWER ONE LINE DIAGRAM  
SCALE: NONE