

REQUEST FOR INFORMATION

ATTN: Mr. Daniel Shea
James E VanZandt VA Medical
Center
2907 Pleasant Valley Blvd
Altoona, PA 16602

Date: 3/2/2012
RFI # S05 RFI 503-11-113
Drawing Ref:

Spec Ref: 1.MP101

PROJECT: S05 RFI 503-10-113/Fire and Smoke Partitions/R.C. Clark Contractors, Inc.

SUBJECT: Fire & Smoke Partitions

INFORMATION REQUESTED:

Are fire and smoke partitions to be checked and repaired the entire length shown (C-1 on drawing 1.mp101 and others) or only the area in which actual work takes place?

Please advise.

Signed: Wayne Eisel, VP of Operations

Date: 3/2/12

REPLY: From Architect/Engineer responsible for the Design.

Only areas affected by demolition and/or new construction need to be checked and repaired.

Signed: Bob Bartolt, KZF Design

Date: 3/5/12