

# TECHNICAL EXHIBIT 1

Item	Unit	Unit Id. / Location	Capacity	Manufacturer & Model	INSPECTION	TESTS			CLIN REQUIREMENTS											
						MONTHLY	CATHODIC PROTECTION BI-MONTHLY	ANNUAL TANK (TTT)	ANNUAL TANKLINE (LTT)	CUN 001	CLIN 002	CLIN 003	CUN 004	CUN 005	CLIN 006	CLIN 007	CUN 008	CLIN 009	CLIN 010	CUN 011
VHASAJ																				
1	Emergency Generator AST-Day Tank #1	EGU No. 2	325 GALLONS	Alonso & Carus	X			X	X											
2	Emergency Generator AST-Day Tank #2	EGU No. 5 CLO	50 GALLONS	Alonso & Carus	X			X	X											
3	Emergency Generator AST-Day Tank #3	EGU No. 6 TANK FARM	225 GALLONS	TRAMONT	X			X	X											
4	Emergency Generator AST-Day Tank #4	EGU No. 7 TANK FARM	225 GALLONS	TRAMONT	X			X	X											
5	Emergency Generator AST-Day Tank #5	EGU No. 8 TANK FARM	225 GALLONS	TRAMONT	X			X	X											
6	Emergency Generator AST-Day Tank #6	EGU No. 9 TANK FARM	225 GALLONS	TRAMONT	X			X	X											
7	Emergency Generator AST-Day Tank #7	EGU No. 10 TANK FARM	225 GALLONS	TRAMONT	X			X	X											
8	Emergency Generator AST-Day Tank #8	EGU No. 11 TANK FARM	225 GALLONS	TRAMONT	X			X	X											
9	Emergency Generator AST-Day Tank #9	EGU No. 12 TANK FARM	225 GALLONS	TRAMONT	X			X	X											
10	Emergency Generator AST-Day Tank #10	EGU No. 13 TANK FARM	225 GALLONS	TRAMONT	X			X	X											
11	Emergency Generator AST-Day Tank #11	EGU No. 14 South Bed Tower	225 GALLONS	TRAMONT	X			X	X											
12	Emergency Generator AST-Day Tank #12	EGU No. 15 Administrative Building	200 GALLONS	TRAMONT	X			X	X											
13	Emergency Generator AST-Day Tank #13	No. 16 / OPA Basement	450 GALLONS	TRAMONT	X			X	X											
14	AST GAS STATION GASOLINE	NEW GAS STATION	10,000 GALLONS	CONVAULT	X			X	X											
15	AST GAS STATION ETHANOL	NEW GAS STATION	10,000 GALLONS	CONVAULT	X			X	X											
16	AST SOUTH BED TOWER	SOUTH BED TOWER	1,000 GALLONS	CONVAULT	X			X	X											
17	AST Administrative Building	ADMINISTRATIVE BUILDING	1000 GALLONS	FLAMESHIELD	X			X	X											
18	AST OUT PATIENT	OUT PATIENT CLINIC (OPA)	650 GALLONS	SOLARES	X			X	X											
19	AST CLO	COMMUNITY LIVING CENTER	1000 GALLONS	CONVAULT	X			X	X											
20	AST BOILER	BOILER	650 GALLONS	ALONSO & CARUS	X				X											
21	AST Gasoline	PARKING D	500 GALLONS	SOLARES	X				X											
22	UNDERGROUND STORAGE TANK	No. 2/ Parking D	30,000 GALLONS	ALONSO & CARUS	X	X			X											
23	UNDERGROUND STORAGE TANK	No. 3/ Parking D BOILER	20,000 GALLONS	XERXES	X				X											
24	UNDERGROUND STORAGE TANK	No. 4 / UST TANK FARM	14,500 gallons	PERMATANK	X				X											
25	UNDERGROUND STORAGE TANK	No. 5 / UST TANK FARM	14,500 gallons	PERMATANK	X				X											
26	UNDERGROUND STORAGE TANK	No. 6 / UST TANK FARM	15,000 GALLONS	PERMATANK	X				X											
27	UNDERGROUND STORAGE TANK	No. 7 / UST TANK FARM	15,000 GALLONS	PERMATANK	X				X											
28	UNDERGROUND STORAGE TANK	No. 8 / UST TANK FARM	15,000 GALLONS	PERMATANK	X				X											
29	UNDERGROUND STORAGE TANK	No. 9 / UST TANK FARM	15,000 GALLONS	PERMATANK	X				X											
30	UNDERGROUND STORAGE TANK	No. 10 / UST TANK FARM	15,000 GALLONS	PERMATANK	X				X											
31	VA Caribbean POPC																			
32	AST DIESEL	No. 1 / PARKING AREA	1,000 GALLONS	SOLARES	X	X														
33	AST DIESEL	No. 1 / PARKING AREA	200 GALLONS	TRAMONT	X															
34	VA Caribbean MOPC																			
35	AST DIESEL	No. 1 / Parking Area	650 GALLONS	ALONSO & CARUS	X	X														

Tasks as per ROW

Task to be conducted if necessary

Task Required

Cathodic Protection Inspection Annual only Ponce & Mayaguez