


- ① REMOVE AND REINSTALL FLOW SWITCH AS REQUIRED FOR DEMOLITION OF EXISTING AND INSTALLATION OF NEW PIPING.
- ② REMOVE EXISTING PRESSURE SWITCH. USE EXISTING CONTROLLER DIGITAL INPUT FOR NEW CURRENT SWITCH ON EXISTING PUMP.

1. EXISTING WIRING, CONDUIT, PNEUMATIC TUBING, AND DEVICES THAT WOULD OTHERWISE BE ABANDONED ON THIS PROJECT SHALL BE REMOVED BY THE CONTRACTOR.

CONSTRUCTION DOCUMENTS 95 % SUBMITTAL		08/12/2005 02/07/2005		 <p>SCHENDT ENGINEERING CORPORATION CONSULTING ENGINEERS * PH. (719) 637-8850 * * FAX (719) 632-0300 * www.schendtengr.com 2912 BEACON ST., COLORADO SPRINGS, CO. 80907</p>						Drawing Title  MECHANICAL CONTROL SCHEMATICS		Project Title  REPLACE COOLING TOWERS		Project Number 575-05-103		OFFICE OF FACILITIES MANAGEMENT	
										Building Number BUILDING NO. 9							
Approved: Medical Center Director —				Location 2121 NORTH AVENUE GRAND JUNCTION, CO 81505						Drawing Number  H8							
Approved: Assistant Administrator, Engineering Department —				Date 08/05/2005		Checked TBS		Drawn DJS		Dwg. 10 of 16							
Revisions		Date															