



SCALE: NONE

NOTE: CHILLED WATER AND CONDENSER WATER ON OPPOSITE ENDS, SEE FLOOR PLAN

NOTE:
CONDENSING DISCHARGE LINE FROM
CHILLERS TO COOLING TOWERS TO BE
PLACED AT A HIGHER ELEVATION AT
COOLING TOWER THAN AT EQUIPMENT
ROOM TO PREVENT OVER FLOW AT
COOLING TOWER SWAMP

MAKE-UP WATER
METER, SEE
SPEC. 1570A

These as-built or record drawings have been prepared, in part, on the basis of information compiled and furnished by others. The [Engineer] will not be responsible for any errors or omissions which have been incorporated into this document as a result.

Drawing Title	Project Title
CHILLED WATER FLOW DIAGRAM	OUTPATIENT/CI INICAL

NO SCALE

ADDITION

NO SCALE

Joint Venture

MCB Architects

Revisions	Date
-----------	------

Date	
------	--

Revisions

Veterans Administration