




three inches = one foot
 one and one half inches = one foot
 one inch = one foot
 three quarters inch = one foot
 one half inch = one foot
 three eighths inch = one foot
 one quarter inch = one foot
 one eighth inch = one foot




28 TYP FULL HEIGHT TILE PARTITION
 SCALE 3" = 1'-0"




23 TYP 4'-1" TILE PARTITION
 SCALE 3" = 1'-0"




18 TYPE H2, H3, H6
 SCALE 3" = 1'-0"




13 TYPE F, F1
 SCALE 3" = 1'-0"



08 TYPES D, D6
 SCALE 3" = 1'-0"



03 TYPES B, B1, B2, B3 (UL#U448)
 SCALE 3" = 1'-0"




PARTITION TYPE S: 25 GA METAL C-H STUDS AT 24" OC W/ 1" SHAFT WALL LINER AND ONE LAYER OF 5/8" GYP BD AT FINISHED SIDE. 20 GA STUD REQUIRED - DEPENDING ON WALLBOARD PRODUCT USED.
 PARTITION TYPE S6: 20 GA METAL STUD IS REQUIRED.


PARTITION TYPE	LIMITING HEIGHT	FIRE RATING
S2	8'-6"	1 HR UL U415, SYSTEM A
S4	13'-4"	1 HR UL U415, SYSTEM A
S6	21'-2" (20gp)	1 HR UL U415, SYSTEM A

DETAIL NOTE: LIMITING HEIGHT BASED ON INTERMITTENT AIR PRESSURE LOAD OF 7.5 PSF.


31 TYPES S2, S4, S6
 SCALE 3" = 1'-0"




26 TYPE K
 SCALE 3" = 1'-0"




21 TYPE J
 SCALE 3" = 1'-0"




16 TYPES G, G1
 SCALE 3" = 1'-0"



11 TYPE E, E1
 SCALE 3" = 1'-0"



06 TYPES C, C1, C4
 SCALE 3" = 1'-0"




01 TYPES A, A1, A2
 SCALE 3" = 1'-0"

Revisions	Date

CONSULTANTS:

Task	Date
SCHEMATIC DESIGN SUBMISSION	08/02/10
DESIGN DEVELOPMENT SUBMISSION	09/03/10
CONSTRUCTION DOCUMENT SUBMISSION	11/22/10
ISSUED FOR BIDS	12/16/11



ARCHITECT/ENGINEERS:
WILSON ARCHITECTURAL GROUP
 5001 WESTHEIMER, SUITE 200 HOUSTON, TEXAS 77056 TELEPHONE (713) 620-6714

MEP ENGINEERS
 STRUCTURAL ENGINEERS
 FIRE PROTECTION ENGINEERS
 CIVIL ENGINEERS

BURNS DeLATTIE and McCOY, INC.
 PINNACLE STRUCTURAL
 PROTECTION DEVELOPMENT INC.
 BREWER and ESCALANTE

DO NOT SCALE THESE DRAWINGS. Q.C. TO FIELD VERIFY DIMENSIONS

Drawing Title: **PARTITION TYPES**

Project Title: **BUILDING 11 ADDITION & INTERIOR RENOVATIONS**

Location: **WACO, TEXAS**

Date: **19 DEC 2011**

Checked:
 Drawn:
 Approved: Project Director

ISSUED FOR BIDS
 Project Number: **674A4-CSI-516**
 Building Number: **11**
 Drawing Number: **11-AS-6.00**
 Dwg. of:
 Fully Sprinklered
 Office of Construction and Facilities Management
 Department of Veterans Affairs