



- ① REMOVE SUPPLY DUCT FROM AIR TERMINAL TO POINTS SHOWN; IF INDICATED, REMOVE ASSOCIATED DIFFUSERS.
- ② REMOVE EXISTING AIR DEVICE, VAV TERMINAL UNIT, HEAT EXCHANGER AND ASSOCIATED DUCTWORK AND HW PIPING AS INDICATED. RETURN TERMINAL UNIT AND HEAT EXCHANGER TO OWNER'S STOCK.
RELOCATED ASSOCIATED THERMOSTAT TO LOCATION SHOWN ON RENO PLAN & CONNECT TO NEW TERMINAL 11-TU-1-4.
- ③ CUT EXIST. DUCT & REMOVE DASHED PORTION & ANY ASSOCIATED DIFFUSERS; MODIFY DUCT PER RENO PLAN.
- ④ REMOVE BRANCH DUCT & ANY ASSOCIATED DIFFUSERS; PATCH TRUNK DUCT AIR TIGHT & REPAIR INSULATION; ENSURE VAPOR BARRIER.
- ⑤ REMOVE DUCTWORK TO POINTS SHOWN; PREPARE EXIST. DUCT FOR MODIFICATION PER RENO PLAN.
- ⑥ RELOCATE EXIST. THERMOSTAT TO NEW POSITION PER RENO PLAN.
- ⑦ REMOVE GRILLE AT BOTTOM OF DUCT, MODIFY DUCT PER RENO PLAN.
- ⑧ RE: RENO PLAN FOR MODIFICATIONS TO THESE AIR TERMINALS & HEAT EXCHANGERS.

CONSULTANTS:			
Date:		12/16/11 Burns, DeLatta & McCoy, Inc. Texas Registered Engineering Firm F-685	

Drawing Title
MECHANICAL LEVEL 1 DEMOLITION PLAN
SCALE: $\frac{1}{4}" = 1' - 0"$
Approved Project Director

Office of
Construction
and Facilities
Management

 Department of
Veterans Affairs