


- ① PROVIDE 208V, 30A, NEMA 14-30 SINGLE RECEPTACLE AND PLUG.
- ② PROVIDE 208V, 20A, NEMA 6-20 SINGLE RECEPTACLE AND PLUG.
- ③ PROVIDE 208V, 50A, NEMA 14-50 SINGLE RECEPTACLE AND PLUG FOR POWER TO RANGE. PROVIDE SHUNT TRIP AT BREAKER IN PANEL. COORDINATE AND PROVIDE NECESSARY CONTROL WIRE/CONDUIT FOR ANSUL SUPPRESSION SYSTEM COORDINATE WITH FIRE PROTECTION ENGINEER.
- ④ PROVIDE 480V, 30A, 3P, NF, NEMA 1 DISCONNECT SWITCH. COORDINATE LOCATION WITH ARCHITECT
- ⑤ TV OUTLET. COORDINATE MOUNTING HEIGHT WITH ARCHITECT.
- ⑥ PROVIDE 120V JBOX FOR POWER TO HOOD. COORDINATE ELEVATION HEIGHT WITH EQUIPMENT MANUFACTURER. PROVIDE SHUNT TRIP AT BREAKER IN PANEL. COORDINATE AND PROVIDE NECESSARY CONTROL WIRE/CONDUIT FOR ANSUL SUPPRESSION SYSTEM. COORDINATE WITH FIRE PROTECTION ENGINEER. PROVIDE LOCAL SWITCH TO CONTROL EXHAUST FAN.
- ⑦ PROVIDE 120V SWITCHED RECEPTACLE FOR DISPOSAL. CONTRACTOR TO PROVIDE SWITCH FOR DISPOSAL.
- ⑧ PROVIDE WALL MOUNTED SWITCH, 208V, 2A, 2 POLE TO CONTROL FIRE PLACE.
- ⑨ PROVIDE 120V POWER TO JBOX FOR WATER CLOSET SENSORS.
- ⑩ PROVIDE 120V POWER TO JBOX FOR DOORS.

Project Title BUILDING 11 ADDITION AND INTERIOR RENOVATIONS			Project Number 674AA-CSI-516		Office of Construction and Facilities Management
			Building Number 11		
Location WACO, TEXAS			Drawing Number 11		
Date 19 DEC 2011	Checked FP	Drawn JL	ES101 Divg of		
					 Department of Veterans Affairs