




1. COORDINATE ALL NEW WORK WITH EXISTING CONDITIONS.
2. ALL DUPLEX RECEPTACLES WITHIN 6 FEET OF A SINK SHALL BE GFCI TYPE.

- ① PROVIDE 208V, 30A, NEMA 14-30 SINGLE RECEPTACLE AND PLUG.
- ② PROVIDE 208V, 20A, NEMA 6-20 SINGLE RECEPTACLE AND PLUG.
- ③ PROVIDE 208V, 50A, NEMA 14-50 SINGLE RECEPTACLE AND PLUG FOR POWER TO RANGE. PROVIDE SHUNT TRIP BREAKER IN PANEL. COORDINATE AND PROVIDE NECESSARY CONTROL WIRE/CONDUIT FOR ANSUL SUPPRESSION SYSTEM. COORDINATE WITH FIRE PROTECTION ENGINEER.
- ④ PROVIDE 480V, 30A, 3P, NF, NEMA 1 DISCONNECT SWITCH. COORDINATE LOCATION WITH ARCHITECT.
- ⑤ V. UTILITY. COORDINATE MOUNTING HEIGHT WITH ARCHITECT.
- ⑥ PROVIDE 120V J-BOX FOR POWER TO HOOD. COORDINATE ELEVATION HEIGHT WITH EQUIPMENT MANUFACTURER. PROVIDE SHUNT TRIP AT BREAKER IN PANEL. COORDINATE AND PROVIDE NECESSARY CONTROL WIRE/CONNECTION FOR ANSUL SUPPRESSION SYSTEM. COORDINATE WITH FIRE PROTECTION ENGINEER. PROVIDE LOCAL SWITCH TO CONTROL EXHAUST FAN.
- ⑦ PROVIDE 120V SWITCH RECEPTACLE FOR DISPOSAL. CONTRACTOR TO PROVIDE SWITCH FOR DISPOSAL.
- ⑧ PROVIDE WALL MOUNTED SWITCH, 208V, 2A, 2 POLE TO CONTROL FIRE PLACE.
- ⑨ PROVIDE 120V POWER TO JBOX FOR WATER CLOSET SENSORS.
- ⑩ PROVIDE 120V POWER TO JBOX FOR AUTOMATIC DOORS.

Project Title <b>BUILDING 11 ADDITION AND INTERIOR RENOVATIONS</b>			Project Number <b>67444-CSI-516</b>		Office of Construction and Facilities Management
Location <b>WACO, TEXAS</b>			Building Number <b>11 -204</b>		
Drawing Number <b>11 204</b>			<b>ES102</b> Dwg. of		
Date <b>19 DEC 2011</b>	Checked <b>FP</b>	Drawn <b>JL</b>			
					Department of Veterans Affairs