



### ELECTRICAL SYMBOL SCHEDULE

HOMERUN TO PANELBOARD. QUANTITY OF ARROWS INDICATES QUANTITY OF CIRCUITS. QUANTITY OF HASH MARKS INDICATES QUANTITY OF NO. 12 AWG CONDUCTORS. NO HASH MARKS INDICATES TWO WIRES

CONDUIT RUN CONCEALED IN WALL OR ABOVE CEILING

CONDUIT RUN CONCEALED IN OR BELOW FLOOR OR UNDERGROUND

CONDUIT RUN EXPOSED. RUN PARALLEL OR PERPENDICULAR TO  
STRUCTURE OR WALL.

PANELBOARD, FLUSH AND SURFACE MOUNTED RESPECTIVELY.

SINGLE POLE SWITCH IN FLUSH OUTLET BOX, 48" ABOVE  
FINISHED FLOOR. UNLESS HEIGHT OTHERWISE NOTED IN PLAN

THREE-WAY SWITCH IN FLUSH OUTLET BOX, 48" ABOVE FINISHED FLOOR.

30-AMP, 125/250-VOLT. -WIRE SINGLE RECEPTACLE. NEMA  
I -30R, HEIGHT AS INDICATED.

NURSE CALL ANNUNCIATOR PANEL. RAULAND # LA8530 IN #BB8531F  
FLUSH BOX.

Department of  
Veterans Affairs