



- KEYED SHEET NOTES:
1. REPLACE EXISTING EXIT SIGN IN PLACE. REUSE EXISTING CIRCUIT.
  2. MAKE CONNECTION TO AN EXISTING UNUSED 20A/1P BRANCH BREAKER MADE AVAILABLE IN DEMOLITION.
  3. ARRANGE LIGHTING FIXTURE AS NEEDED TO ELIMINATE CONFLICT WITH NEW HVAC EQUIPMENT.
  4. SWITCH 'Sa' SHALL CONTROL, VIA CONTACTOR, CIRCUITS 6P-2,4,6, AND 12. SWITCH 'Sb' SHALL CONTROL, VIA CONTACTOR, CIRCUITS 6P-8,10,14, AND 16.
  5. EXISTING LIGHTING SHALL REMAIN.

- GENERAL SHEET NOTES:
- A. ALL EMERGENCY EGRESS LUMINAIRES AND EXIT SIGNS SHALL BE WIRED AHEAD OF ALL LOCAL SWITCHES.

NOTE:

THIS DRAWING IS NOT AS-BUILT AND IS  
TO BE USE FOR INFORMATION ONLY AND  
IS TO BE VERIFY BY THE CONTRACTOR  
BEFORE ANY DESIGN/CONSTRUCTION  
TAKES PLACE.

[illegible]

RECOMMEND APPROVAL			
REQUESTER	Date		
CHIEF OF SERVICE	Date	CHIEF OF STAFF	Date
ASSOC. DIR. PATIENT CARE SVC.	Date	ASSOC. DIR. for OPERATIONS	Date
APPROVAL BY:			Date
MEDICAL CENTER DIRECTOR			

	Drawing Title
	GROUND FLOOR LIGHTING PLAN
e	FOR B-G RECORD
	STORAGE/EDUCATION RESOURCE
e	Approved: Safety Manager/M&O Supervisor
e	Approved: Chief of Facilities Management Svr.

Project Title <b>BUILDING #6 RENOVATION (EDUCATIONAL CENTER)</b>		
Building Number BUILDING #G	Checked	Drawn BLF
Location W.G.(Bill) Hefner Medical Center 1601 Brenner Ave. Salisbury NC 28144		

Date	05 DEC 2011
Project No.	659-12-201
DRAWING NO.	E-101
DWG. 4 OF 10	



Department of Veterans Affairs