



44 Bancroft Mills
Wilmington, DE 19806
Ph: 302.655.5492
Fax: 302.655.8491

REQUEST FOR INFORMATION

From: Patriot GS

To: Department of Veterans Affairs

Attn: Michael White

RFI No. 001

Solicitation #VA244-12-B-0896

Project #460-10-209

Requested By: Dan Pawling

Project Name: Renovate Canteen Kitchen

Date: 3/27/12

Trade: Abatement

Dwg. No's: AR102

Spec. Section(s)

Please provide the following information:

Please provide clarification on Asbestos Abatement for Corridor #2077 and service vestibule, Storage Closet #2059 for floor tile. Are these the only areas to have asbestos abatement work, and are there additional areas that have been requested by your office to have asbestos abatement at floor tile areas?

Answer: You are responsible for the removal of all asbestos within the work areas of the SOW. As per the SOW you are to test all areas for Asbestos. I have included an attachment of the VA's assessment for asbestos but this in no way stops you from conducting your own! Nor is this report to be taken as 100% correct!



44 Bancroft Mills
Wilmington, DE 19806
Ph: 302.655.5492
Fax: 302.655.8491

If you have any questions or require additional information please call me at 302-254-4005.
Thank you !