

**RFI FORM****Contractor Name:** Walker Telecomm, Inc.**Address:** 1995 Highway 65, Wheatland, CA 95692**Phone/eMail:** john@walkertelecomm.com**Send to:** Karen.smith 3@va.gov

---

**RFI  
(REQUEST FOR INFORMATION)**

<b>PROJECT NO.:</b>	662-618	<b>RFI NO.:</b>	003
<b>PROJECT NAME:</b>	Expand Clinical Operating Rooms & Surgery Bldg. 200	<b>DATE REQUESTED:</b>	9/29/16
<b>SOLICITATION NO.:</b>	VA261-16-B-0473	<b>REFERENCE:</b>	Telecomm
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	27

**DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED**

Please be specific as possible:  
for the telecomm portion of this project are we to demo everything back to the existing IDF rooms and then reinstall? so in the end we will only be providing new cabling and new connectors such as jacks?

**PROJECT MANAGER'S RESPONSE**

Per Technology Demolition Plans, unless otherwise noted, existing telecommunications systems devices and associated conduit and cable in noted areas shall be demolished back to IDF room. Label all empty ports as spare. Provide new data outlets and cabling as noted on new telecommunications systems floor plans.

**TRACKING NO.:**  
RFI 003**AMENDMENT NO.:**  
A00008**VA PROJECT ENGINEER/MANAGER:**  
Curtis Wood**DATE:** 11-30-2016