RFI FORM

Contractor Name: FEDCO LLC.

Address: 1792 Bell Tower Lane, Weston, FL 33326

Phone/eMail: 786-412-7287 - odelin@fedcollc.com

Send to: Karen.smith 3@va.gov

RFI
(REQUEST FOR INFORMATION)

PROJECT NO.:	662-618	**RFI NO.:**	004
PROJECT NAME:	Expand Clinical Operating Rooms & Surgery Bldg. 200	**DATE REQUESTED:**	10/07/2016
SOLICITATION NO.:	VA261-16-B-0473	**REFERENCE:**	11 73 00 Specs.
DRAWING:	A10.03 Equipment Schedule	**SPECIFICATION SECTION:**	11 73 00 CEILING MOUNTED PATIENT LIFTS.

DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED

Please be specific as possible:

The 11 73 00 Ceiling Mounted Patient Lifts, specifies a 440 lbs. Motor, but the drawing A10.03 Equipment Schedule specifies a GH3 Lift System, this GH3 is 440 to 550 lbs Motor.
Which Motor weight capacity do you want a 440 lbs. or a 550 lbs?

PROJECT MANAGER'S RESPONSE

Please see new specification 11 73 00 and updated drawing A10.3 Equipment schedule uploaded, this specification and drawing replace the old specification 11 73 00 and A10.3 drawing.

TRACKING NO.: RFI 004	**AMENDMENT NO.:** A00008
VA PROJECT ENGINEER/MANAGER: Curtis Woods	**DATE:** 11/30/2017