

RFI FORM

Contractor Name: Fidelis Sustainability Distribution LLC (Dustin Lee) GULDMANN

Address: 204 West Spear St Carson City, NV 89703

Phone/Fax: 775-301-5390

Send to: Karen.Smith3@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	662-618	RFI NO.:	006
PROJECT NAME:	Expand Clinical Operating Rooms & Surgery Bldg. 200	DATE REQUESTED:	12/01/2016
SOLICITATION NO.:	VA26116B0473	REFERENCE:	
DRAWING:	S3.5	SPECIFICATIONSECTION:	
DESCRIPTION OF PROBLEM OR INFOMRATION BEING REQUESTED			
<p>Please be specific as possible:</p> <p>Can any and all detail be given as to the individual patient lift system weight requirements per each clinical room. IE: which rooms will be receiving the 1000# lifts? Are all the rooms requiring a 1000lbs lift? If not please supply the break down as per your requirement.</p>			
A/E RESPONSE			
<p><i>See sheet S3.5</i></p> <p><i>Only 'BARIATRIC LIFTS' will require 1000lbs of lift. Two bariatric lifts are required in the PACU. All other lifts to have a minimum 600lb lift capacity.</i></p>			
TRACKING NO.: RFI 006		AMENDMENT NO.: A00009	
VA PROJECT ENGINEER/MANAGER: Travis Dilts		DATE: 12/7/2016	