



GENERAL VIEW OF MASTIC



GENERAL VIEW OF MASTIC



GENERAL VIEW OF MASTIC



GENERAL VIEW OF MASTIC



TYPICAL JOINTS



TYPICAL JOINTS



GENERAL VIEW OF MASTIC



GENERAL VIEW OF MASTIC



GENERAL VIEW OF MASTIC




GENERAL VIEW OF MASTIC




GENERAL VIEW OF MASTIC



- ASBESTOS ABATEMENT NOTES:
1. GENERAL CONTRACTOR SHALL HIRE A CERTIFIED INDUSTRIAL HYGIENIST (CIH) TO VERIFY THE ABATEMENT QUANTITIES PRIOR TO START OF ABATEMENT IN EACH CONTAINMENT.
 2. DEMOLITION REFERS TO HVAC DEMOLITION DRAWINGS AND PLUMBING DRAWINGS.
FOR THE EXTENT OF THE DEMOLITION, SCOPE OF THE WORK INCLUDES REMOVAL OF ALL ASBESTOS CONTAINING MASTIC ON PIPES AND DUCTS THROUGHOUT.
 3. MASTIC ON SUPPLY DUCTS AND EXHAUST DUCTS & PIPES AT JOINTS AND CONNECTION SURFACES SHOULD BE REMOVED PRIOR TO THE DEMOLITION OF THE DUCTS AND PIPES. ALTERNATIVELY, ABATEMENT CONTRACTOR MAY DEMO AND DISPOSE OF MASTIC COVERED DUCTS AND PIPES UNDER CONTAINMENT AS ASBESTOS CONTAINING MATERIALS.
 4. COORDINATE ALL ABATEMENT WORK WITH MECHANICAL AND PLUMBING CONTRACTOR.
 5. REMOVE ALL PIPE JOINT INSULATION (50) AS ASBESTOS CONTAINING MATERIALS.
 6. REMOVE DRAIN PANS (2) AS ASBESTOS CONTAINING MATERIAL.



ATTIC FLOOR PLAN
ASBESTOS ABATEMENT PLAN
0 2 4 6 8 16
GRAPHIC SCALE (FEET)



CONSTRUCTION DOCUMENTS

 <div>Tennessee Valley Healthcare System</div>		 <div>MURFREESBORO CAMPUS</div>		Approved: --		Approved: Facility Manager		Project Title REPLACE ATTIC AHU'S BLDG 6		Date 1/20/2012	
Revisions		Date		Approved: --		Approved: Director		Building Number 6		Checked AKU	
								Location VAMC --		Drawn JFG	
								DRAWING NO. 6-AB 1		FILE NAME 1-AB 2	

Veterans
Administration