

three inches = one foot  
one and one half inches = one foot  
one inch = one foot  
three quarters inch = one foot  
one half inch = one foot  
three eighths inch = one foot  
one quarter inch = one foot  
one eighth inch = one foot

1 FIRST FLOOR PLAN-POWER  
SCALE: 1/8" = 1'-0"  
BLD: 11

SCHEMATIC DESIGN SUBMISSION	08/02/10
DESIGN DEVELOPMENT SUBMISSION	09/03/10
CONSTRUCTION DOCUMENT SUBMISSION	11/22/10
ISSUE FOR BIDS	12/19/11
ADDENDUM No 04	04/05/12
Revisions	Date

CONSULTANTS:



ARCHITECT/ENGINEERS:

WILSON ARCHITECTURAL GROUP  
5051 WESTHEIMER, SUITE 800 HOUSTON, TEXAS 77056 TELEPHONE (713) 621-8774

MEP ENGINEERS  
STRUCTURAL ENGINEERS  
FIRE PROTECTION ENGINEERS  
CIVIL ENGINEERS

BURNS DeLATTE AND McCOY, INC.  
PINNACLE STRUCTURAL  
PROTECTION DEVELOPMENT INC.  
BREWER AND ESCALANTE

Drawing Title  
FIRST FLOOR  
PLAN- POWER  
SCALE: 1/8" = 1'-0"

Approved Project Director

Project Title  
BUILDING 11 ADDITION AND  
INTERIOR RENOVATIONS

Location  
WACO, TEXAS

Date  
19 DEC 2011

Checked  
FP

Drawn  
JL

Project Number  
674A4-CSI-516  
Building Number  
11  
Drawing Number  
11  
ES101R  
Dwg. of

Office of  
Construction  
and Facilities  
Management



GENERAL NOTES

- COORDINATE ALL NEW WORK WITH EXISTING CONDITIONS.
- ALL DUPLEX RECEPTACLES WITHIN 6 FEET OF A SINK SHALL BE GFCI TYPE.

KEYED NOTES

- PROVIDE 208V, 30A, NEMA 14-30 SINGLE RECEPTACLE AND PLUG.
- PROVIDE 208V, 20A, NEMA 6-20 SINGLE RECEPTACLE AND PLUG.
- PROVIDE 208V, 50A, NEMA 14-50 SINGLE RECEPTACLE AND PLUG FOR POWER TO RANGE. PROVIDE SHUNT TRIP AT BREAKER IN PANEL. COORDINATE AND PROVIDE NECESSARY CONTROL WIRE/CONDUIT FOR ANSUL SUPPRESSION SYSTEM. COORDINATE WITH FIRE PROTECTION ENGINEER.
- PROVIDE 480V, 30A, 3P, NF, NEMA 1 DISCONNECT SWITCH. COORDINATE LOCATION WITH ARCHITECT.
- TV OUTLET. COORDINATE MOUNTING HEIGHT WITH ARCHITECT.
- PROVIDE 120V JBOX FOR POWER TO HOOD. COORDINATE ELEVATION HEIGHT WITH EQUIPMENT MANUFACTURER. PROVIDE SHUNT TRIP AT BREAKER IN PANEL. COORDINATE AND PROVIDE NECESSARY CONTROL WIRE FOR CONNECTION TO ANSUL SUPPRESSION SYSTEM. COORDINATE WITH FIRE PROTECTION ENGINEER. PROVIDE LOCAL SWITCH TO CONTROL EXHAUST FAN.
- PROVIDE 120V SWITCHED RECEPTACLE FOR DISPOSAL CONTRACTOR TO PROVIDE SWITCH FOR DISPOSAL.
- PROVIDE WALL MOUNTED SWITCH, 208V, 20A, 2 POLE TO CONTROL FIRE PLACE.
- PROVIDE 120V POWER TO JBOX FOR WATER CLOSET SENSORS.
- PROVIDE 120V POWER TO JBOX FOR DOORS.
- POWER FOR SMOKE DAMPER. COORDINATE WITH MECHANICAL PLANS FOR FINAL LOCATION.