

**REQUEST FOR INFORMATION (RFI)**  
**VA250-17-B-0049**

PROJECT NUMBER:	655-13-113	<b>Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.</b>	
PROJECT TITLE:	Nurse Call System		
PROJECT LOCATION:	Department of Veterans Affairs Aleda E. Lutz Medical Center 1500 Weiss Street Saginaw, MI 48602		
SUBMITTED BY:	Robbert Construction	City/State:	Lakeview, Michigan
PHONE NO.:	989-287-7612		

**TO:**

Kyle Lipper, Contracting Officer  
Department of Veterans Affairs  
Attn: 90 CSC  
24 Frank Lloyd Wright Dr.  
Lobby M, Suite M2200  
Ann Arbor, MI 48105  
[Kyle.lipper@va.gov](mailto:Kyle.lipper@va.gov)

<b>RFI NO.: 004</b>	<b>DATE: 01/10/17</b>	<b>SPEC/DWG. REFERENCE:</b>
<b>REPLY NEEDED BY:</b>		

**INFORMATION NEEDED:**

Is there sufficient wireless coverage presently in the areas of operation?

**REPLY:**

YES

**REVIEWED**

*By Tom Belongia at 1:20 pm, Jan 17, 2017*

REPLY FROM:	DATE:
ATTACHMENTS:	COPY TO: