

REQUEST FOR INFORMATION (RFI)
VA250-17-B-0049

PROJECT NUMBER:	655-13-113	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Nurse Call System		
PROJECT LOCATION:	Department of Veterans Affairs Aleda E. Lutz Medical Center 1500 Weiss Street Saginaw, MI 48602		
SUBMITTED BY:	Robbert Construction	City/State:	Lakeview, Michigan
PHONE NO.:	989-287-7612		

TO:

Kyle Lipper, Contracting Officer
Department of Veterans Affairs
Attn: 90 CSC
24 Frank Lloyd Wright Dr.
Lobby M, Suite M2200
Ann Arbor, MI 48105
Kyle.lipper@va.gov

RFI NO.: 006	DATE: 01/10/17	SPEC/DWG. REFERENCE:
REPLY NEEDED BY:		

INFORMATION NEEDED:

Nurse Call plotted on the DWG AutoCAD files show Duty Stations at the end of corridors whereas the PDF Floor Plans do not. Which is correct?

REPLY:

The existing duty station stations are ceiling mounted as work-around to provide better audio alarm coverage in the corridors for the existing system. The new design is not anticipated to have this issue, therefore they are not depicted on the new plans nor are they desired. Thank you for double-checking.

REVIEWED

By Tom Belongia at 4:28 pm, Jan 13, 2017

REPLY FROM: Phillip Nicholson	DATE: 2017.01.12
ATTACHMENTS:	COPY TO: