

REQUEST FOR INFORMATION (RFI)
VA250-17-B-0049

PROJECT NUMBER:	655-13-113	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Nurse Call System		
PROJECT LOCATION:	Department of Veterans Affairs Aleda E. Lutz Medical Center 1500 Weiss Street Saginaw, MI 48602		
SUBMITTED BY:	Government	City/State:	
PHONE NO.:			

TO:

Kyle Lipper, Contracting Officer
Department of Veterans Affairs
Attn: 90 CSC
24 Frank Lloyd Wright Dr.
Lobby M, Suite M2200
Ann Arbor, MI 48105
Kyle.lipper@va.gov

RFI NO.: 018G	DATE:01/19/2017	SPEC/DWG. REFERENCE: Network Cabling
REPLY NEEDED BY:		

INFORMATION NEEDED:

The specifications references the use of category 6 cable throughout the project.

REPLY:

Cat 6 cabling is only required where it interfaces to the Government IT Network. All interconnects between nurse call devices can utilize Category 5e if acceptable by the manufacturer.

REPLY FROM:	APPROVED	DATE:	
ATTACHMENTS:	By Tom Belongia at 3:33 pm, Jan 19, 2017		