BEAM SCHEDULE

MARK	SIZE W	SIZE D	REINFORCING LONGITUDINAL No. SIZE	REMARKS	STIRRUPS No. SIZE	SPACING EACH END
3B-149	32	14½	5 - #6	BOTT.	*	
			4 - #8	TOP@GRID'5'	38	#3 1@6"; 6@12"
			2 - #6	TOP@'4', 90°HK		
3B-150	50	14½	7 - #6	BOTT.	*	
			8 #8	TOP@GRID 'G'	40	#3 1@6"; 5@12"
			4 - #6	TOP@'5', 90°HK		
3B-151	50	14½	10 #7	BOTT.	*	
			7 #11	TOP@GRID 'T'	24	#4 2@5"; 9@6"; 1@12"
			SEE R-1-533-1			
3B-152	50	14½	10 - #7	BOTT.	*	
			10 - #9	TOP@GRID B	24	#4 2@5"; 9@6"; 1@12"
3B-153	50	14½	10 - #7	BOTT. 90°HK@GRID 'B'.	*	
			10 - #9	TOP@GRID'9', 90°HK	24	#4 2@5"; 9@6"; 1@12"
3B-154	50	14½	8 - #8	BOTT. 90°HK@GRID '6'	*	
			11 - #9	TOP@GRID '7'	24	#4 2@5"; 9@6"; 1@12"
			11 - #9	TOP@GRID '6', 90°HK		
3B-155	50	14½	8 - #8	BOTT.	*	
			11 - #9	TOP@GRID B	24	#4 2@5"; 9@6"; 1@12"
3B-156	50	14½	8 #8	BOTT.	*	
					24	#4 2 @5"; 9@6"; 1@12"
			4 - #9	TOP@'9', 90°HK		
			5 - #9	BOTT. 90°HK@GRID'10'	*	
3B-157	25	18	8 - #10	TOP@GRID'10', 90°HK	42 -	#3 4@4", 3@5"; 11@6" 3@12".
			7 - #11	TOP@'9'		
			5 - #6	BOTT. 90°HK@GRID'9'	*	4@4"; 3@5"; 11@6"
3B-158	35	14½	7 - #7	TOP@GRID'10'	42	#3 3@12".
			6 - #7	TOP@GRID'9', 90°HK		
			7 - #6	BOTT.	*	4@4"; 3@5"; 11@6";
3B-159	47½	14½	8 - #7	TOP@GRID'11'	42	#3 3@12".
			2 - #6	TOP @'10', 90°HK		
			7 #6	BOTT.	*	4@4"; 3@5", 11@6"
3B-160	47½	14½	8 #7	TOP@GRID'12'	42	#3 3@12".
			7 #6	BOTT.	*	4@5"; 3@5"; 11@6"
3B-161	47½	14½	8 #7	TOP@GRID '13'	42	#3 3@12".
			7 #6	BOTT., 90°HK@'14'	*	4@4"; 3@5"; 11@6"
3B-162	47½	14½	8 #6	TOP@GRID '14', 90°HK	42	#3 3@12".
			7 - #9	BOTT. 90°HK@GRID'G'	*	2@5"; 9@5"; 1@12"
3B-163	50	14½	7 #11	TOP@GRID'7'	24	#4
			7 #11	TOP@GRID'G'		
			10 #7	BOTT.	*	2@5"; 9@6"; 1@12"
3B-164	50	14½	7 #11	TOP@GRID'8'	24	#4
			9 - #7	BOTT.	*	
3B-165	50	14½	7 - #6	TOP@GRID '9'	24	#4 2@5"; 9@6"; 1@12"
			3 #8	BOTT, 90°HK EACH END		
3B-166	12	14½			11	#3 @ 12"
			3 #8	TOP CONTINUOUS	(TIES)	
			2 #8	BOTT.		1@4", 3@6", 1@10"
3B-167	8/	14½			12 # 3	1@15".
	13½		2 #8	TOP CONT. 90°HK EA.END	(TIES)	
			4 #7	BOTT., 90°HK@GRID'9'		1@4", 3@5", 3@6", 7@8"
3B-168	23	18	5 #9	TOP@GRID'10.2'	34 #4	3@16"
			5 #9	TOP@GRID'9', 90° HK		
			6 #8	BOTT.		1@4", 3@5", 3@6", 7@8"
3B-169	23	18	7 #9	TOP@GRID'10.8'	28 #4	
			4 #7	BOTT.	*	7@5", 11@12"
3B-170	23	18	7 #8	TOP@GRID'12'	36 #4	
			5 #7	BOTT.		12@6", 6@10"
3B-171	23	18	5 #9	TOP@GRID'13'	36 #4	
			6 #7	BOTT, 90°HK@GRID'14'		1@4", 3@5", 3@6", 7@8"
3B-172	20	18	6 #8	TOP@GRID'14', 90°HK	32 #4	2@16"
			8 #7	BOTT. 90°HK@GRID'6'	*	1@5", 2@6", 6@8"
3B-173	50	18	9 #9	TOP@GRID'7.2'	20	#3 1@16".
			7 #9	TOP@GRID'8', 90°HK		
			8 #9	BOTT.	*	2@3", 3@4", 2@5", 1@6",
3B-174	50	18	8 #9	TOP@GRID'8'	26	#3 4@8", 1@16"
			8 #9	BOTT.	*	2@3", 3@4", 2@5", 1@6",
3B-175	50	18	4 #9	TOP@GRID B.9, 90°HK	26	#3 4@8", 1@16".
			SEE REVISED SCHEDULE R-1-GS-B			
			7 #7	BOTT, 90°HK@GRID'10.2	*	5@6"; 9@10", 2@16"
3B-176	17	18	7 #7	TOP@GRID'10.2', 90°HK	32	#3
			5 #9	TOP@'8.9'		
			3 - #7	BOTT.		1@4"; 4@5", 4@6";
3B-177	18	18	3 - #9	TOP@GRID 'B.9', 180°HK	42 -	#3 11@8"; 1@16"
			2 - #7	BOTT.		1@4", 4@5", 4@6",
3B-178	20	18	3 - #9	TOP@GRID'10.2', 90°HK	42 -	#3 11@8", 1@16"
			3 - #9	TOP@GRID'8.9', 180°HK		
			2 - #7	BOTT.		3@5"; 3@6"; 7@8",
3B-179	15	18	3 - #9	TOP@GRID'8.9'	34 -	#4 4@16".

MARK	SIZE W	SIZE D	REINFORCING LONGITUDINAL No. SIZE	REMARKS	STIRRUPS No. SIZE	SPACING EACH END
3B-180	16½	18	3 #8	BOTT.		3@5"; 5@6"; 7@8";
			2 #7	TOP@GRID'10.2'	34 -	#4 4@16".
3B-181	8	18	3 #7	BOTT. 90°HK@GRID'5.6'		1@4"; 2@5"; 1@6"; 2@8
			2 #9	TOP@GRID 'G'	14 -	#3 1@16".
			2 #6	TOP LAPPED @	→ 2-#9, TOP@GRID'5.6', 90°HK	
3B-182	18	18	2 #7	BOTT.		1@4"; 3@5", 2@6", 6@8"
			3 #7	TOP@GRID '7.2'	26 -	#3 1@16".
			2 #7	BOTT.		
3B-183	15	18	2 #7	TOP@'8'	18	#4 1@4", 2@5", 1@6";
			2 #5	TOP LAPPED @	→ 2#8 TOP@'5.6', 90°HK	5@8".
			2 #7	BOTT.		
3B-184	15	18	2 #8	TOP@GRID'7.2'	30	#4 1@4"; 3@5"; 3@6" 6@8".
			6 #8	BOTT. 90°HK@GRID'5.6'		1@4"; 2@5"; 1@6";
3B-185	22	18	4 #6	TOP@GRID'5.6', 90°HK	16	#4 4@8"
			4 #5	TOP LAPPED @	→ 6#8 TOP@'6'	
			6 #8	BOTT.		1@4"; 2@5"; 1@6"; 6@8"
3B-186	22	18	6 #10	TOP@'7.2'	24	#4 2@16".
			5 #5	TOP LAPPED		
			6 #7	BOTT.		16@4", 9@5"; 1@10";
3B-187	24	18	6 #10	TOP@GRID '8.9'	56	#4 2@16"
			6 #6	BOTT.		2@6"; 5@8, 5@10";
3B-188	20½	18	6 #9	TOP@'10.2'	30	#4 3@16".
			6 #9	BOTT. 90°HK@'10.8'		1@4"; 2@5"; 1@6";
3B-189	24	18	5 #9	TOP@GRID '10.8', 90°HK	24	#4 6@8", 2@16"
			5 #6	BOTT. 90°HK@GRID'5.6'		3@4"; 2@5"; 6@6"
3B-190	19	14½	5 #5	TOP@GRID'6'	22 -	#3
			4 #5	TOP LAPPED @	→ 5-#6 TOP@GRID'5.6', 90°HK	
			5 - #5	BOTT.		3@4"; 2@5", 12@6".
3B-191	19	14½	4 - #6	TOP@GRID 'U.4'	34	#3
			3 #8	BOTT. 90°HK EA. END		
3B-192	12	14½			11	#3 @ 12"
			3 #8	TOP CONT.	(TIES)	
			5 #8	BOTT.		1@3", 5@6", 10@8"
3B-193	16	24	5 #9	TOP@GRID '10.2'	38	#3 3@12".
			3 #9	TOP@GRID '8.9'		
			6 #7	BOTT.		1@2", 4@4", 3@5", 3@6"
3B-194	18	22½			44	#3 6@8", 5@12".
			6 #7	TOP CONT. 90°HK, EA.END		
			4 #6	BOTT., 90°HK@GRID'1'		1@4", 3@5"; 3@6", 7@8"
3B-195	20½	18	6 #6	TOP@GRID '2'	32	#4 2@16"
			5 #6	TOP@ GRID'1', 90°HK	(TIES)	
			5 #6	BOTT.		1@4"; 3@5", 3@6", 7@8"
3B-196	20½	18	7 #6	TOP@GRID'3'	32	#4 2@16".
			SEE R-1-533-2		(TIES)	
			5 #6	BOTT.		1@4"; 3@5"; 3@6"; 7@8"
3B-197	20½	18	7 #6	TOP@GRID'4'	32	#4 2@16"
					(TIES)	
			4 #6	BOTT.		1@4", 3@5"; 3@6";
3B-198	20½	18	7 #6	TOP@GRID'5'	34	#4 7@8"; 3@16".
					(TIES)	
			5 #6	BOTT.		1@4"; 3@5"; 3@6";
3B-199	20½	18	9 #6	TOP@GRID'6'	36	#4 7@8"; 3@16".
					(TIES)	
			9 #6	BOTT.		1@4"; 2@5", 1@6",
3B-200	20½	18	6 #11	TOP@GRID'7.2'	22	#4 5@8"; 2@16"
					(TIES)	
			5 #9	BOTT.		
3B-201	24	18	6 #11	TOP@GRID'J.9'	44 #4	20@6", 2@16"
					(TIES)	
			5 #6	BOTT.		8@8", 6@10", 2@16"
3B-202	24	18	6 #9	TOP@GRID'10.2'	32	#4
					(TIES)	
			6 #8	BOTT.		1@4"; 3@5", 3@6",
3B-203	24	18	6 #9	TOP@GRID'10.8'	30	#4 8@8".
					TIES	
			6 #8	BOTT.		1@4"; 2@5", 1@6";
3B-204	24	18	6 #8	TOP@GRID '11.6'	20	#4 5@8"; 1@16"
					(TIES)	
			5 #6	BOTT.		1@4", 3@5", 3@6"
3B-205	24	18	6 #7	TOP@GRID'12.8'	36	#4 7@8", 4@16".
					(TIES)	
			5 #6	BOTT, 90°HK@'14'		1@4"; 3@5"; 3@6";
3B-206	24	18	5 #7	TOP@GRID '14', 90°HK	36	#4 7@8"; 4@16".
					(TIES)	
			6 #7	BOTT.		1@2", 4@4", 3@5",
3B-207	18	22½	FCO No 61 10-15-65		44	#3 3@6", 6@8", 5@12"
			6 #7	TOP CONT. 90°HK EA. END		
3B-208	12	34½	2 - #9	BOTT. 90°HK@GRID'K'		1@5", 2@6", 1@8", 1@10"
			2 - #9	TOP@GRID'L'	18 -	#3 4@12".
			2 #9	TOP@GRID'K', 90°HK	(TIES)	
			2 - #9	BOTT.		1@5", 2@6", 1@8", 1@10"
3B-209	12	34½	2 - #9	TOP@GRID 'M.2'	18 -	#3 2@12", 2@18".
					(TIES)	
			2 - #9	BOTT.		1@5", 2@6, 1@8", 1@10"
3B-210	12	34½	2 - #9	TOP@GRID 'N'	16 -	#3 3@12".
					(TIES)	

MARK	SIZE W	SIZE D	REINFORCING LONGITUDINAL No. SIZE	REMARKS	STIRRUPS No. SIZE	SPACING EACH END
3B-211	12	34½	2 - #9	BOTT.		1@5", 2@6", 1@8", 1@10"
			2 - #9	TOP@GRID 'R.5'	20 -	#3 2@12", 3@18".
					(TIES)	
3B-212	12	34½	2 - #9	BOTT.		3@6", 2@8", 1@10", 1@12"
			2 - #9	TOP@GRID 'Q.4'	20 -	#3 2@16", 1@18"
					(TIES)	
3B-213	12	34½	2 - #9	BOTT.		1@5", 2@6", 1@8", 1@10"
			2 - #9	TOP@GRID 'R'	18 -	#3 2@12", 2@18".
					(TIES)	
3B-214	12	34½	2 - #9	BOTT.		3@6", 2@8", 1@10", 1@12"
			2 - #9	TOP@GRID 'R.9'	22 -	#3 2@16", 2@18".
					(TIES)	
3B-215	12	34½	2 - #9	BOTT.		3@6", 2@8", 1@10", 1@12"
			2 - #9	TOP@GRID 'T.1'	24 -	#3 2@16", 3@18"
					(TIES)	
3B-216	12	34½	2 - #9	BOTT.		3@6", 2@8", 1@10", 1@12"
			2 - #9	TOP@GRID 'U'	22 -	#3 2@16". 2@18".
					(TIES)	
3B-217	12	34½	2 - #9	BOTT. 90°HK@GRID 'V'		3@6", 2@8", 1@10", 1@12"
			2 - #9	TOP@GRID'V', 90°HK.	22 -	#3 2@16", 2@18".
					(TIES)	
3B-218	50	14½	7 - #6	BOTT. 90°HK@GRID 'K'	*	2@5", 9@6", 2@12"
			10 #7	TOP@GRID'L'	26 -	#4
			8 #6	TOP@GRID'K', 90°HK		
3B-219	50	14½	7 - #6	BOTT.	*	2@5", 9@6", 2@12"
			10 #7	TOP@GRID'M'	26 -	#4
			SEE R-1-533-2			
3B-220	50	14½	7 - #6	BOTT.	*	2@5", 9@6", 2@12".
			9 - #7	TOP@GRID'N'	26 -	#4
3B-221	50	14½	7 - #6	BOTT.	*	2@5", 8@6"
			8 - #6	TOP@GRID'P'	20 -	4
			4 - #5	TOP, LAPPED		
3B-222	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 - #7	TOP@GRID'Q'	40 -	#3 5@8", 2@16".
3B-223	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 #7	TOP@GRID'R'	40 -	#3 5@8", 2@16"
3B-224	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 - #7	TOP@GRID'S'	40 -	#3 5@8", 2@16"
3B-225	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 - #7	TOP@GRID'T'	40 -	#3 5@8", 2@16".
3B-226	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			7 - #8	TOP@GRID'U'	40 -	#3 5@8", 2@16".
3B-227	50	18	7 - #7	BOTT. 90°HK@GRID'V'	*	3@3", 5@4", 3@5", 2@6"
			7 - #7	TOP@GRID'V', 90° HK	40 -	#3 5@8", 2@16"
3B-228	12	14½	3 #8	BOTT. 90°HK. EA. END		
			3 #8	TOP. CONT.	11	#3 @ 12"
			2 #10	BOTT., 90°HK @ EA. END	(TIES)	
3B-229	8	34½	2 #10	TOP CONT. 90°HK@EA.END	34	#3 3@3", 5@4", 3@6", 4@12"
					(TIES)	
3B-230	12	14½	3 #8	BOTT. 90°HK EA. END		
			3 #8	TOP CONT.	11	#3 @ 12"
			3 #8	BOTT. 90°HK. EA. END	(TIES)	
3B-231	12	14½			11	#3 @ 12"
			3 #8	TOP CONT.	(TIES)	
			7 #6	BOTT., 90°HK@GRID'K'	*	3@5", 4@6", 2@8", 3@10"
3B-232	35	18	6 - #9	TOP@GRID'L'	24 -	4
			6 #9	TOP@GRID'K', 90°HK		
			7 - #6	BOTT.	*	2@5", 5@6", 2@10", 2@12"
3B-233	35	18	8 - #9	TOP@GRID'M'	22 -	#4
			8 #6	BOTT. SEE R-1-533-2	*	2@5", 9@6", 2@12"
3B-234	50	14½	10 #7	TOP@GRID'N'	26 -	#4
			2 #7	TOP@'M', 90°HK		
			7 - #6	BOTT.	*	2@5", 8@6"
3B-235	50	14½	8 - #6	TOP@GRID'P'	20 -	4
			4 - #5	TOP, LAPPED		
3B-236	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 - #7	TOP@GRID'Q'	40 -	#3 5@8"
3B-237	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 - #7	TOP@GRID'R'	40 -	#3 5@8", 2@16"
3B-238	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 - #7	TOP@GRID'S'	40 -	#3 5@8", 2@16".
3B-239	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 - #7	TOP@GRID'T'	40 -	#3 5@8", 2@16"
3B-240	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			7 - #8	TOP@GRID'U'	40 -	#3 5@8", 2@16"
3B-241	50	18	7 - #7	BOTT. 90°HK@GRID'V'	*	3@3", 5@4", 3@5", 2@6"
			7 - #7	TOP@GRID'V', 90°HK	40 -	#3 5@8", 2@16"

MARK	SIZE W	SIZE D	REINFORCING LONGITUDINAL No. SIZE	REMARKS	STIRRUPS No. SIZE	SPACING EACH END
3B-242	50	14½	9 - #6	BOTT. 90°HK@GRID'K'	*	
			8 - #9	TOP@GRID'L'	26	#4 2@5"; 9@6"; 2@12"
			8 - #9	TOP@GRID'K', 90°HK		
3B-243	50	14½	7 - #6	BOTT.	*	
			8 #9	TOP@GRID'M'	26	#4 2@5"; 9@6"; 2@12"
			SEE R-1-533-2			
3B-244	50	14½	7 - #7	BOTT.	*	
			10 - #7	TOP@GRID 'N'	26	#4 2@5"; 9@6"; 2@12"
			8 - #7	BOTT.	*	
3B-245	50	14½	7 - #7	TOP@GRID'P'	20	#4 2@5" ; 8@6"
			5 - #4	TOP, LAPPED		
			7 - #7	BOTT.	*	
3B-246	50	18	7 #8	TOP@GRID'Q'	40	#3 3@3", 5@4", 3@5" 2@6", 5@8", 2@16"
			7 #7	BOTT.	*	3@3", 5@4", 3@5"
3B-247	50	18	8 #7	TOP@GRID'R'	40	#3 2@6"
			7 #7	BOTT.	*	3@3", 5@4", 3@5"
3B-248	50	18	8 #7	TOP@GRID'S'	40	#3 2@6"; 5@8"; 2@16"
			7 #7	BOTT.	*	3@3", 5@4", 3@5"
3B-249	50	18	8 #7	TOP@GRID'T'	40	#3 2@6"; 5@8"; 2@16"
			7 #7	BOTT.	*	5@4", 3@5", 2@6";
3B-250	50	18	8 #8	TOP@GRID'U'	40	#3 5@8"; 2@16"
			8 #7	BOTT. 90°HK@GRID'V'	*	5@4", 3@5", 2@6";
3B-251	50	18	7 #7	TOP@GRID'V', 90°HK	40	#3 5@8", 2@16".
			9 - #6	BOTT. 90°HK@GRID 'K'	*	
3B-252	50	14½	8 - #9	TOP@GRID'L'	24	#4 2@5"; 9@6"; 1@12"
			8 - #9	TOP@GRID'K', 90°HK.		
			7 - #6	BOTT.	*	
3B-253	60	14½	8 - #9	TOP@GRID'M'	24	#4 2@5", 9@6"; 1@12"
			8 - #6	BOTT.	*	
3B-254	50	18	10 #7	TOP@GRID 'N'	24	#4
			SEE R-1-533-2			
			8 - #7	BOTT.	*	2@5" ; 8@6"
3B-255	50	14½	8 - #7	TOP@GRID'P'	20	#4
			5 - #6	TOP, LAPPED		
			7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
3B-256	50	18	8 - #7	TOP@GRID'Q'	40 -	#3 5@8", 2@16"
			7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
3B-257	50	18	8 - #7	TOP@ GRID'R'	40 -	#3 5@8", 2@16".
			7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
3B-258	50	18	8 - #7	TOP@ GRID'S'	40	#3 5@8", 2@16"
			7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
3B-259	50	18	8 - #7	TOP@GRID'T'	40 -	#3 5@8", 2@16".
			7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
3B-260	50	18	7 - #8	TOP@GRID'U'	40 -	#3 5@8", 2@16".
			7 - #7	BOTT. 90°HK@GRID'V'	*	3@3", 5@4", 3@5", 2@6"
3B-261	50	18	7 - #7	TOP@GRID'V', 90°HK	40	#3 5@8", 2@16".
			8 - #7	BOTT. 90°HK@GRID'K'	*	
3B-262	50	14½	8 - #9	TOP@GRID'L'	26	#4 2@5", 9@6", 2@ 12"
			7 #9	TOP@GRID'K', 90°HK		
			7 - #6	BOTT.	*	
3B-263	50	14½	8 - #9	TOP@GRID'M'	26	#4 2@5", 9@6", 2@12".
			SEE R-1-533-2			
			7 - #6	BOTT.	*	2@5", 9@6", 2@12"
3B-264	50	14½	10 - #7	TOP@GRID'N'	26 -	#4
			7 - #7	BOTT.	*	
3B-265	50	14½	8 - #9	TOP@ GRID'P'	20 -	#4 2@5", 8@6"
			8 - #7	BOTT.	*	5@4", 2@5", 2@6", 7@8"
3B-266	50	18	9 - #9	TOP@ GRID'Q'	36 -	#4 2@16"
			7 - #7	BOTT.	*	5@4", 2@5", 2@6", 7@8"
3B-267	50	18	8 - #9	TOP@GRID'R'	36 -	#4 2@16"
			7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
3B-268	50	18	8 - #7	TOP@GRID'S'	40 -	#3 5@8", 2@16".
			7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
3B-269	50	18	8 - #7	TOP@GRID'T'	40 -	#3 5@8", 2@16"
			7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
3B-270	50	18	7 - #8	TOP@GRID'U'	40 -	#3 5@8", 2@16".
			7 - #7	BOTT. 90°HK@GRID'V'	*	3@3", 5@4", 3@5", 2@6"
3B-271	50	18	7 - #7	TOP@GRID'V', 90°HK	40 -	#3 5@8", 2@16".
			7 - #7	BOTT. 90°HK@GRID'K'	*	
3B-272	50	14½	8 - #9	TOP@GRID'L'	26	#4 2@5", 9@6", 2@12".
			8 #9	TOP@GRID'K', 90°HK		

MARK	SIZE W	SIZE D	REINFORCING LONGITUDINAL No. SIZE	REMARKS	STIRRUPS No. SIZE	SPACING EACH END
3B-273	50	14½	7 - #6	BOTT.	*	2@5", 9@6", 2@12.
			8 - #9	TOP@GRID 'M'	26	#4
3B-274	50	18	8 - #6	BOTT.	*	2@5", 9@6", 2@12".
			8 - #8	TOP@GRID'N'	26	#4
			SEE R-1-533-2			
3B-275	50	14½	7 - #7	BOTT.	*	2@5", 8@6"
			10 - #7	TOP@GRID'P'	20	#4
			4 - #6	TOP, LAPPED		
3B-276	50	18	7 - #9	BOTT.	*	5@4"; 2@5", 2@6",
			11 - #9	TOP@GRID 'Q'	36 -	#4 7@8"; 2@16"
3B-277	50	18	7 - #8	BOTT.	*	5@4"; 2@5"; 2@6";
			9 #9	TOP@GRID'R'	36	#4 7@8"; 2@16"
3B-278	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 - #7	TOP@GRID'S'	40 -	#3 5@8", 2@16".
3B-279	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5", 2@6"
			8 #7	TOP@ GRID'T'	40 -	#3 5@8", 2@16".
3B-280	50	18	7 - #7	BOTT.	*	3@3", 5@4", 3@5",
			7 - #8	TOP@GRID'U'	40 -	#3 2@6"; 5@8"; 2@16"
3B-281	50	18	7 - #7	BOTT. 90°HK@GRID'V'	*	3@3", 5@4", 3@5", 2@6"
			7 - #7	TOP@GRID'V', 90°HK.	40 -	#3 5@8", 2@16".
3B-282	32	14½	5 - #6	BOTT. 90°HK@GRID'5.8'		4@4"; 3@5"; 11@6"
			4 #8	TOP@GRID '7.4'	42	#3 3@12".
			4 #8	TOP@GRID '5.8', 90°HK		
3B-283	32	14½	5 #6	BOTT.		4@4"; 3@5"; 11@6"
					42	#3 3@12"
3B-284	19	18	3 - #7	BOTT.	*	1@4"; 2@5"; 1@6"
			2 - #8	TOP@GRID 8.8 INTO 3B-285	20	#4 5@8"; 1@16".
			2 #8	TOP @ GRID'8.8', 90°HK		
3B-285	50	14½	8 #7	BOTT. 90°HK@GRID'G'	*	1@3", 4@4", 1@5"
			12 #9	TOP@GRID'7.2'	28	#4 6@6"; 2@12"
			7 - #11	TOP@GRID'G', 90°HK		
3B-286	50	14½	9 #9	BOTT.	*	2@5", 9@6", 2@12
			12 #9	TOP@GRID 'B'	26	#4
			10 #7	BOTT.	*	2@ 5"; 9@6", 2@12"
3B-287	50	14½	7 - #6	TOP@GRID'9'	26	#4
			7 - #5	TOP LAPPED		
			8 - #7	BOTT.	**	1@4"; 2@5"; 8@6";
3B-288	50	14½	10 - #9	TOP@GRID'9.5'	26	#4 2@12".
			9 - #9	TOP@GRID'8.8'		
			7 - #6	BOTT.	*	1@5"; 4@4"; 1@5"
3B-289	50	14½	8 - #8	TOP@GRID'10.5'	28	#4 6@6"; 2@12".
			7 - #6	BOTT.	*	1@5"; 4@4"; 1@5"
3B-290	50	14½	8 - #8	TOP@GRID '10.8'	28	#4 6@6"; 2@12".
			7 - #6	BOTT. 90°HK@GRID'11.6'	*	1@5"; 4@4", 1@5";
3B-291	50	14½	9 - #6	TOP@GRID '11.6', 90°HK.	26	#4 6@6" ; 1@12".
			7 #7	BOTT. 90°HK@GRID'K'	*	9@4", 3@5" ; 2@10
3B-292	50	18	9 #9	TOP@ GRID 'L'	30	#4 1@12"
			8 #8	TOP@GRID'K', 90°HK		
			8 #6	BOTT.	*	3@4"; 2@5"; T@6";
3B-293	50	14½	12 #8	TOP@GRID'M'	28	#3 2@12"
			7 #7	BOTT.	*	3@3"; 10@4"; 3@12
3B-294	50	18	8 #7	TOP@GRID'N'	32 -	4
			8 #9	BOTT.	*	2@3", 3@4", 2@5";
3B-295	50	18	11 #9	TOP@GRID 'P'	22 -	3 1@6"; 3@8".
			4 #6	TOP, LAPPED		
			7 #7	BOTT.	*	1@4", 3@5", 3@6", 7@8"
3B-296	50	18	12 #8	TOP@GRID 'Q'	32	#4 2@16".

*: DOUBLE STIRRUPS OR TIES; **: TRIPLE STIRRUPS OR TIES.

NOTE:
STIRRUP SPACING FROM FACE OF SUPPORT
SEE SHEET 1-556 & 1-568

1-2-2-1990

ALL ADDENDUM, CLARIFICATION AND CHANGE ORDER DATA HAVE BEEN POSTED TO THIS DRAWING. THIS SHEET AS IS COMPLETE AND UP TO DATE AS OF 05-5-67

3RD FLOOR BEAM SCHEDULES
BUILDING NO. 1
1062 BED
M. S. & N. HOS