⬡SHEET KEYNOTES

1. CONTRACTOR TO UPGRADE EXISTING PNEUMATIC CONTROLS TO DIRECT DIGITAL CONTROLS AND ADD ADDITIONAL CONTROL DEVICES ON EXISTING AIR HANDLER UNIT. SEE SCHEDULE FOR INDIVIDUAL POINTS AND CORRESPONDING DETAILS.
2. EXISTING EXHAUST FAN TO REMAIN.



1 B.1 THIRD FLOOR MECHANICAL CONTROLS UPGRADE PLAN
SCALE: 1/16"=1'-0"

NORTH



Revisions: REVISION 1	JUNE 22

CONSULTANTS:

ARCHITECT/ENGINEERS:

SPECTRUM ENGINEERS
324 S. State St., Suite 400
Salt Lake City, UT 84111
800-678-7077
801-328-5151
fax: 801-328-5155
www.spectrum-engineers.com

Drawing Title: B.1 THIRD FLOOR MECHANICAL CONTROLS UPGRADE PLAN

Approved: Project Director

Project Title: METASYS CONTROLS AND ENERGY UPGRADE PHASE III ADDENDUM A

Location: -

Date: 2/2012 | Checked: RXP | Drawn: TNB

Project Number: 660-12-110

Building Number: B.1

Drawing Number: MI103-B01
Dwg. 8 of 14

Office of Construction and Facilities Management
Department of Veterans Affairs

VA FORM 08-6231

File Name: P:\2010\20100329\Archive\Y1A PH3 & VA PH3A\Phase III Addendum A\Drawings\36MI103-B01.dwg Last Plotted: 2012/04/03 @ 9:47 AM By: Vrastkryanj