

RFI FORM

Contractor Name:

Address:

Phone/Fax:

send to: cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	002
PROJECT NAME:	REMEDIATE Water Intrusion Damage	DATE REQUESTED:	01/25/2017
SOLICITATION NO.:	VA262-17-Q-0293	REFERENCE:	Pipe Supports
DRAWING:	N/A	SPECIFICATION SECTION:	N/A
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
At the Site Visit [Job Walk], the existing pipe supports were visible to the attendees. Can these existing pipe supports be re-used if found to be serviceable?			
PROJECT MANAGER'S RESPONSE			
Yes. Reuse the existing pipe supports.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: TIM CONROY		DATE: 1/25/2017	